

## TO BE RESCINDED

1301:7-7-06 **Building services and systems.**

## (A) Section 601 General

- (1) 601.1 Scope. The provisions of this rule shall apply to the installation, operation and maintenance of fuel-fired appliances and heating systems, emergency and standby power systems, electrical systems and equipment, mechanical refrigeration systems, elevator recall, stationary storage battery systems and commercial kitchen hoods.
- (2) 601.2 Permits. Permits shall be obtained for refrigeration systems and battery systems as set forth in rule 1301:7-7-01 of the Administrative Code.

## (B) Section 602 Definitions

- (1) 602.1 Definitions. The following words and terms shall, for the purposes of this rule and as used elsewhere in this code, have the meanings shown herein.

"Battery system, stationary lead acid." A system which consists of three interconnected subsystems:

1. A lead-acid battery.
2. A battery charger.
3. A collection of rectifiers, inverters, converters, and associated electrical equipment as required for a particular application.

"Battery types."

"Nickel cadmium (Ni-Cd) battery." An alkaline storage battery in which the positive active material is nickel oxide, the negative contains cadmium and the electrolyte is potassium hydroxide.

"Nonrecombinant battery." A storage battery in which, under conditions of normal use, hydrogen and oxygen gases created by electrolysis are vented into the air outside of the battery.

"Recombinant battery." A storage battery in which, under conditions of normal use, hydrogen and oxygen gases created by electrolysis are converted back into water inside the battery instead of venting into the air outside of the battery.

"Stationary storage battery." A group of electrochemical cells interconnected

*Note: for copyright claim information, please see the notice on the last page of this rule.*

to supply a nominal voltage of DC power to a suitably connected electrical load, designed for service in a permanent location. The number of cells connected in a series determines the nominal voltage rating of the battery. The size of the cells determines the discharge capacity of the entire battery. After discharge, it may be restored to a fully charged condition by an electric current flowing in a direction opposite to the flow of current when the battery is discharged.

"Valve-regulated lead-acid (VRLA) battery." A lead-acid battery consisting of sealed cells furnished with a valve that opens to vent the battery whenever the internal pressure of the battery exceeds the ambient pressure by a set amount. In VRLA batteries, the liquid electrolyte in the cells is immobilized in an absorptive glass mat (AGM cells or batteries) or by the addition of a gelling agent (gel cells or gelled batteries).

"Vented (Flooded) lead-acid battery." A lead-acid battery consisting of cells that have electrodes immersed in liquid electrolyte. Flooded lead-acid batteries have a provision for the user to add water to the cell and are equipped with a flame-arresting vent which permits the escape of hydrogen and oxygen gas from the cell in a diffused manner such that a spark, or other ignition source, outside the cell will not ignite the gases inside the cell.

[M] "Commercial cooking appliances." Appliances used in a commercial food service establishment for heating or cooking food and which produce grease vapors, steam, fumes, smoke or odors that are required to be removed through a local exhaust ventilation system. Such appliances include deep fat fryers; upright broilers; griddles; broilers; steam-jacketed kettles; hot-top ranges; under-fired boilers (charbroilers); ovens; barbecues; rotisseries; and similar appliances. For the purpose of this definition, a food service establishment shall include any building or a portion thereof used for the preparation and serving of food.

[M] "Hood." An air-intake device used to capture by entrapment, impingement, adhesion or similar means, grease and similar contaminants before they enter a duct system.

"Type I." A kitchen hood for collecting and removing grease vapors and smoke.

"Refrigerant." The fluid used for heat transfer in a refrigerating system; the refrigerant absorbs heat and transfers it at a higher temperature and a higher pressure, usually with a change of state.

"Refrigeration system." A combination of interconnected refrigerant-containing parts constituting one closed refrigerant circuit in which a refrigerant is circulated for the purpose of extracting heat.

*Note: for copyright claim information, please see the notice on the last page of this rule.*

(C) Section 603 Fuel-fired appliances

- (1) 603.1 Installation. The installation of nonportable fuel gas appliances and systems shall comply with the International Fuel Gas Code as listed in rule 1301:7-7-45 of the Administrative Code. The installation of all other fuel-fired appliances other than internal combustion engines, oil lamps and portable devices such as blow torches, melting pots and weed burners, shall comply with this paragraph, and the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code.
- (a) 603.1.1 Manufacturer's instructions. The installation shall be made in accordance with the manufacturer's instructions and applicable federal, state, and local rules and regulations. Where it becomes necessary to change, modify, or alter a manufacturer's instructions in any way, written approval shall first be obtained from the manufacturer.
- (b) 603.1.2 Approval. The design, construction and installation of fuel-fired appliances shall be in accordance with the International Fuel Gas Code and the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code.
- (c) 603.1.3 Electrical wiring and equipment. Electrical wiring and equipment used in connection with oil-burning equipment shall be installed and maintained in accordance with paragraph (E)(605) of this rule and the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code.
- (d) 603.1.4 Fuel oil. The grade of fuel oil used in a burner shall be that for which the burner is approved and as stipulated by the burner manufacturer. Oil containing gasoline shall not be used. Waste crankcase oil shall be an acceptable fuel in Group F, M and S occupancies, when utilized in equipment listed for use with waste oil and when such equipment is installed in accordance with the manufacturer's instructions and the terms of its listing.
- (e) 603.1.5 Access. The installation shall be readily accessible for cleaning hot surfaces; removing burners; replacing motors, controls, air filters, chimney connectors, draft regulators, and other working parts; and for adjusting, cleaning and lubricating parts.
- (f) 603.1.6 Testing, diagrams and instructions. After installation of the oil-burning equipment, operation and combustion performance tests

*Note: for copyright claim information, please see the notice on the last page of this rule.*

shall be conducted to determine that the burner is in proper operating condition and that all accessory equipment, controls, and safety devices function properly.

- (i) 603.1.6.1 Diagrams. Contractors installing industrial oil-burning systems shall furnish not less than two copies of diagrams showing the main oil lines and controlling valves, one copy of which shall be posted at the oil-burning equipment and another at an approved location that will be accessible in case of emergency.
  - (ii) 603.1.6.2 Instructions. After completing the installation, the installer shall instruct the owner or operator in the proper operation of the equipment. The installer shall also furnish the owner or operator with the name and telephone number of persons to contact for technical information or assistance and routine or emergency services.
  - (g) 603.1.7 Clearances. Working clearances between oil-fired appliances and electrical panelboards and equipment shall be in accordance with the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code. Clearances between oil-fired equipment and oil supply tanks shall be in accordance with NFPA 31 as listed in rule 1301:7-7-45 of the Administrative Code.
- (2) [B, M, FG] 603.2 Chimneys. Masonry chimneys shall be constructed in accordance with the building code as listed in rule 1301:7-7-45 of the Administrative Code. Factory-built chimneys shall be installed in accordance with the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code. Metal chimneys shall be constructed and installed in accordance with NFPA 211 as listed in rule 1301:7-7-45 of the Administrative Code.
- (3) 603.3 Fuel oil storage systems. Fuel oil storage systems shall be installed in accordance with this code. Fuel oil piping systems shall be installed in accordance with the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code.
- (a) 603.3.1 Maximum outside fuel oil storage aboveground. Where connected to a fuel-oil piping system, the maximum amount of fuel oil storage allowed outside above ground without additional protection shall be 660 gallons (2498 L). The storage of fuel oil above ground in quantities exceeding 660 gallons (2498 L) shall comply with NFPA 31 as listed in rule 1301:7-7-45 of the Administrative Code.

*Note: for copyright claim information, please see the notice on the last page of this rule.*

- (b) 603.3.2 Maximum inside fuel oil storage. Where connected to a fuel-oil piping system, the maximum amount of fuel oil storage allowed inside any building shall be 660 gallons (2498 L). Where the amount of fuel oil stored inside a building exceeds 660 gallons (2498 L), the storage area shall be in compliance with the building code as listed in rule 1301:7-7-45 of the Administrative Code.
- (c) 603.3.3 Underground storage of fuel oil. The storage of fuel oil in underground storage tanks shall comply with NFPA 31 as listed in rule 1301:7-7-45 of the Administrative Code.
- (4) 603.4 Unvented heaters. Portable unvented fuel-fired heating equipment shall be prohibited in occupancies in Groups A, E, I, R-1, R-2, R-3 and R-4. Portable kerosene-fired space or room heaters shall be equipped with an automatic extinguishing tip-over device. Any natural gas-fired or liquid petroleum gas-fired space or room heater shall be equipped with an oxygen depletion safety shutoff system and the source of fuel shall be piped from a location outside the building. All unvented heaters shall be marked by the manufacturer in some conspicuous manner that the heater has been approved and listed by one of the authoritative sources listed in rule 1301:7-7-01 of the Administrative Code.
- Exception: Listed and approved unvented fuel-fired heaters in one- and two-family dwellings.
- (a) 603.4.1 Prohibited locations. Unvented fuel-fired heating equipment shall not be located in, or obtain combustion air from, any of the following rooms or spaces: sleeping rooms, bathrooms, toilet rooms or storage closets. No unvented kerosene heater shall be located in any building means of egress.
- (b) 603.4.2 Elevation not permitted. No unvented kerosene heater shall be elevated by being placed upon a stand or otherwise placed or suspended above the floor.
- (c) 603.4.3 Placement restrictions. No unvented kerosene heater shall be placed within three feet of any furniture, drapery, curtain, decorative material, accessory, appliance, equipment, merchandise, goods, or fixture, or any other thing, which is or may be combustible.
- (d) 603.4.4 Must be attended. No unvented kerosene heater shall be left unattended while it is operating.

*Note: for copyright claim information, please see the notice on the last page of this rule.*

- (e) 603.4.5 Non-combustible mat required. Every unvented kerosene heater shall be set and centered upon a noncombustible mat or shallow base, the dimensions of which shall be sufficient to allow at least three feet of the mat or base to extend outward in any direction from any part of the unvented kerosene heater.
- (f) 603.4.6 Ventilation required. Every unvented kerosene heater shall be used in an area where there is adequate ventilation, as recommended by the manufacturer of such heater.
- (g) 603.4.7 Cool-down required. No unvented kerosene heater shall be fueled or refueled while it is operating or within ten minutes of flame extinguishment, or contrary to the instructions of its manufacturer.
- (h) 603.4.8 Fueling prohibited. No unvented kerosene heater or its fuel reservoir shall be fueled or refueled inside a building. All such fueling operations shall be performed outdoors.
- (i) 603.4.9 Fueling guidelines. Every unvented kerosene heater shall be fueled or refueled strictly in accordance with the instructions of its manufacturer.
- (j) 603.4.10 Fuel requirements. The fuel in every unvented kerosene heater shall be only No. 1-K kerosene as prescribed in paragraph (F)(9)(3406.9) of rule 1301:7-7-34 of the Administrative Code.
- (k) 603.4.11 Fuel storage. The fuel used in every unvented kerosene heater shall be stored away from occupied areas and in an approved container which shall be marked or labeled in a conspicuous manner to read: "1-K kerosene".
- (l) 603.4.12 Fire extinguisher requirements. At least one fire extinguisher with a minimum 2-A, 20-B:C rating and capacity shall be provided and available for use within twenty-five feet of every unvented kerosene heater during its operation.
- (m) 603.4.13 Manufacturer's instructions. No person shall sell or offer for sale any kerosene heater in this state unless the manufacturer has provided instructions for operating the heater and certain information about its use, which shall include the following:

*Note: for copyright claim information, please see the notice on the last page of this rule.*

- (i) All pertinent information bearing upon the assembly and installation of the heater.
- (ii) All pertinent information bearing upon the proper operation, maintenance, and storage of the heater.
- (iii) All pertinent information which might reasonably bear upon the health or life safety of persons in the vicinity of the heater if recommended assembly, installation, operational, or maintenance procedures are not respected.
- (iv) All safety features incorporated in the heater shall be described.
- (v) Instructions for starting or lighting the heater, regulating its flame or heat, and turning it off or extinguishing its flame.
- (vi) Proper fueling procedures shall be set forth.
- (vii) A cautionary warning that the heater may be extremely hot while in operation; that, therefore, it may burn, injure, or damage any person or thing contacting it; and that, in particular, infants, children, physically or mentally incompetent persons, and pets should be kept away from the unit.
- (viii) A cautionary warning that the heater may be extremely hot while in operation; that, therefore, the heat radiating from it may ignite any combustible thing in close proximity; that it should not be placed within three feet of any furniture, drapery, curtain, clothing, or other thing which is or may be combustible; that, however, the heater may be placed against or within three feet of a combustible wall, provided the heater is specifically designed for such installation or placement.
- (ix) A cautionary warning that the heater may be extremely hot while in operation; that, therefore, no fueling procedure, including the removal of the fuel reservoir, should be carried out while the unit is operating and until it has cooled down.
- (x) A cautionary warning that the heater should not be moved while it is in operation.

*Note: for copyright claim information, please see the notice on the last page of this rule.*

- (xi) A cautionary warning that neither the heater nor any surface of the heater should be used for the purpose of cooking or warming food, unless the heater is specifically designed for cooking and warming food.
  - (xii) A cautionary warning that no additive for the heater's fuel with a flashpoint below one hundred degrees fahrenheit shall be used.
  - (xiii) The recommended minimum room size for the Btu output of the heater shall be set forth.
  - (xiv) The type and grade of fuel the heater is designed to use shall be set forth, together with any safety or fire hazard which might be involved if improper fuel is used.
  - (xv) A cautionary warning for every unvented kerosene heater, warning that when the heater is in operation the combustion process uses oxygen from the space being heated and returns carbon monoxide to the atmosphere as a product of combustion; that, without adequate ventilation, the depletion of oxygen may present a risk of asphyxiation; and that carbon monoxide is a colorless, odorless, highly poisonous gas which, without adequate ventilation, may cause headache, dizziness, and nausea, or even be fatal.
  - (xvi) The ventilation requirements necessary for the safe operation of every unvented kerosene heater shall be set forth.
  - (xvii) A cautionary warning for every unvented kerosene heater, warning that the fuel used in such heater should be restricted to No. 1-K kerosene, as prescribed in this code, or "Fresh, High Quality, Crystal Clear Kerosene."
- (n) 603.4.14 Issuance of citation. If the fire marshal, his authorized representative, or a certified fire safety inspector finds that the use of an unvented kerosene heater or the storage of its fuel is not in compliance with the provisions of this rule, he shall issue a citation to the responsible person as authorized by section 3737.42 of the Revised Code.
- (5) 603.5 Heating appliances. Heating appliances shall be listed and shall comply with this paragraph.

*Note: for copyright claim information, please see the notice on the last page of this rule.*



- (a) 603.5.1 Guard against contact. The heating element or combustion chamber shall be permanently guarded so as to prevent accidental contact by persons or material.
  - (b) 603.5.2 Heating appliance installation and maintenance. Heating appliances shall be installed and maintained in accordance with the manufacturer's instructions, the mechanical code, the International Fuel Gas Code, the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code.
- (6) 603.6 Chimneys and appliances. Chimneys, incinerators, smokestacks or similar devices for conveying smoke or hot gases to the outer air and the stoves, furnaces, fireboxes or boilers to which such devices are connected, shall be maintained so as not to create a fire hazard.
- (a) 603.6.1 Masonry chimneys. Masonry chimneys that, upon inspection, are found to be without a flue liner and that have open mortar joints which will permit smoke or gases to be discharged into the building, or which are cracked as to be dangerous, shall be repaired or relined with a listed chimney liner system installed in accordance with the manufacturer's installation instructions or a flue lining system installed in accordance with the requirements of the building code as listed in rule 1301:7-7-45 of the Administrative Code and appropriate for the intended class of chimney service.
  - (b) 603.6.2 Metal chimneys. Metal chimneys which are corroded or improperly supported shall be repaired or replaced.
  - (c) 603.6.3 Decorative shrouds. Decorative shrouds installed at the termination of factory-built chimneys shall be removed except where such shrouds are listed and labeled for use with the specific factory-built chimney system and are installed in accordance with the chimney manufacturer's installation instructions.
  - (d) 603.6.4 Factory-built chimneys. Existing factory-built chimneys that are damaged, corroded or improperly supported shall be repaired or replaced.
  - (e) 603.6.5 Connectors. Existing chimney and vent connectors that are damaged, corroded or improperly supported shall be repaired or replaced.

*Note: for copyright claim information, please see the notice on the last page of this rule.*

- (7) 603.7 Discontinuing operation of unsafe heating appliances. The fire code official is authorized to order that measures be taken to prevent the operation of any existing stove, oven, furnace, incinerator, boiler or any other heat-producing device or appliance found to be defective or in violation of code requirements for existing appliances after giving notice to this effect to any person, owner, firm or agent or operator in charge of the same. The fire code official is authorized to take measures to prevent the operation of any device or appliance without notice when inspection shows the existence of an immediate fire hazard or when imperiling human life. The defective device shall remain withdrawn from service until all necessary repairs or alterations have been made.
- (a) 603.7.1 Unauthorized operation. It shall be a violation of this code for any person, user, firm or agent to continue the utilization of any device or appliance (the operation of which has been discontinued or ordered discontinued in accordance with paragraph (C)(7)(603.7) of this rule, unless written authority to resume operation is given by the fire code official. Removing or breaking the means by which operation of the device is prevented shall be a violation of this code.
- (8) 603.8 Incinerators. Commercial, industrial and residential-type incinerators and chimneys shall be constructed in accordance with the building code, the mechanical code, and the International Fuel Gas Code as listed in rule 1301:7-7-45 of the Administrative Code.
- (a) 603.8.1 Residential incinerators. Residential incinerators shall be of an approved type.
- (b) 603.8.2 Spark arrestor. Incinerators shall be equipped with an effective means for arresting sparks.
- (c) 603.8.3 Restrictions. Where the fire code official determines that burning in incinerators located within 500 feet (152 m) of mountainous, brush or grass-covered areas will create an undue fire hazard because of atmospheric conditions, such burning shall be prohibited.
- (d) 603.8.4 Time of burning. Burning shall take place only during approved hours.
- (e) 603.8.5 Discontinuance. The fire code official is authorized to require incinerator use to be discontinued immediately if the fire code official determines that smoke emissions are offensive to occupants of

*Note: for copyright claim information, please see the notice on the last page of this rule.*

surrounding property or if the use of the incinerators is determined by the fire code official to constitute a hazardous condition.

- (9) 603.9 Gas meters. Above-ground gas meters, regulators and piping subject to damage shall be protected by a barrier complying with paragraph (L)(312) of rule 1301:7-7-03 of the Administrative Code or otherwise protected in an approved manner.

(D) Section 604 Emergency and standby power systems

- (1) 604.1 Installation. Emergency and standby power systems required by this code or the building code as listed in rule 1301:7-7-45 of the Administrative Code shall be installed in accordance with this code, NFPA 110 and NFPA 111 as listed in rule 1301:7-7-45 of the Administrative Code. Existing installations shall be maintained in accordance with the original approval.

- (a) 604.1.1 Stationary generators. Stationary emergency and standby power generators required by this code shall be listed in accordance with UL 2200 as listed in rule 1301:7-7-45 of the Administrative Code.

- (2) 604.2 Where required. Emergency and standby power systems shall be provided where required by paragraphs (D)(2)(a)(604.2.1) to (D)(2)(s)(iv)(604.2.19.4) of this rule.

- (a) 604.2.1 Group A occupancies. Emergency power shall be provided for emergency voice/alarm communication systems in Group A occupancies in accordance with paragraph (G)(2)(l)(ii)(907.2.12.2) of rule 1301:7-7-09 of the Administrative Code.

- (b) 604.2.2 Smoke control systems. Standby power shall be provided for smoke control systems in accordance with paragraph (I)(11)(909.11) of rule 1301:7-7-09 of the Administrative Code.

- (c) 604.2.3 Exit signs. Emergency power shall be provided for exit signs in accordance with paragraph (K)(5)(c)(1011.5.3) of rule 1301:7-7-10 of the Administrative Code.

- (d) 604.2.4 Means of egress illumination. Emergency power shall be provided for means of egress illumination in accordance with paragraph (F)(3)(1006.3) of rule 1301:7-7-10 of the Administrative Code.

- (e) 604.2.5 Accessible means of egress elevators . Standby power shall be

*Note: for copyright claim information, please see the notice on the last page of this rule.*

provided for elevators that are part of an accessible means of egress in accordance with paragraph (G)(4)(1007.4) of rule 1301:7-7-10 of the Administrative Code.

- (f) 604.2.6 Accessible means of egress platform lifts. Standby power in accordance with this paragraph or ASME A18.1 as listed in rule 1301:7-7-45 of the Administrative Code shall be provided for platform lifts that are part of an accessible means of egress in accordance with paragraph (G)(5)(1007.5) of rule 1301:7-7-10 of the Administrative Code.
- (g) 604.2.7 Horizontal sliding doors. Standby power shall be provided for horizontal sliding doors in accordance with paragraph (H)(1)(c)(iii)(1008.1.3.3) of rule 1301:7-7-10 of the Administrative Code.
- (h) 604.2.8 Semiconductor fabrication facilities. Emergency power shall be provided for semiconductor fabrication facilities in accordance with paragraph (C)(15)(1803.15) of rule 1301:7-7-18 of the Administrative Code.
- (i) 604.2.9 Membrane structures. Emergency power shall be provided for exit signs in temporary tents and membrane structures in accordance with paragraph (C)(12)(f)(i)(2403.12.6.1) of rule 1301:7-7-24 of the Administrative Code. Standby power shall be provided for auxiliary inflation systems in permanent membrane structures in accordance with the building code as listed in rule 1301:7-7-45 of the Administrative Code.
- (j) 604.2.10 Hazardous materials. Emergency or standby power shall be provided in occupancies with hazardous materials in accordance with paragraphs (D)(7)(2704.7) and (E)(1)(e)(2705.1.5) of rule 1301:7-7-27 of the Administrative Code.
- (k) 604.2.11 Highly toxic and toxic materials. Emergency power shall be provided for occupancies with highly toxic or toxic materials in accordance with paragraphs (D)(2)(b)(viii)(3704.2.2.8) and (D)(3)(b)(vi)(3704.3.2.6) of rule 1301:7-7-37 of the Administrative Code.
- (l) 604.2.12 Organic peroxides. Standby power shall be provided for occupancies with organic peroxides in accordance with paragraph (D)(1)(k)(3904.1.11) of rule 1301:7-7-39 of the Administrative Code.

*Note: for copyright claim information, please see the notice on the last page of this rule.*

- (m) 604.2.13 Pyrophoric materials. Emergency power shall be provided for occupancies with silane gas in accordance with paragraphs (F)(2)(c)(4106.2.3) and (F)(4)(c)(4106.4.3) of rule 1301:7-7-41 of the Administrative Code.
- (n) 604.2.14 Covered mall buildings. Covered mall buildings exceeding 50,000 square feet (4645 m<sup>2</sup>) shall be provided with standby power systems which are capable of operating the emergency voice/alarm communication.
- (o) 604.2.15 High-rise buildings. Standby power, light and emergency systems in high-rise buildings shall comply with the requirements of paragraphs (D)(2)(o)(i)(604.2.15.1) to ((D)(2)(o)(iii)(604.2.15.3) of this rule.
- (i) 604.2.15.1 Standby power. A standby power system shall be provided. Where the standby system is a generator set inside a building, the system shall be located in a separate room enclosed with 2-hour fire barriers or horizontal assemblies constructed in accordance with the building code as listed in rule 1301:7-7-45 of the Administrative Code, or both. System supervision with manual start and transfer features shall be provided at the fire command center.
- (a) 604.2.15.1.1 Fuel supply. An on-premises fuel supply, sufficient for not less than 2-hour full-demand operation of the system, shall be provided.
- Exception: When approved, the system shall be supplied by natural gas pipelines.
- (b) 604.2.15.1.2 Capacity. The standby system shall have a capacity and rating that supplies all equipment required to be operational at the same time. The generating capacity is not required to be sized to operate all of the connected electrical equipment simultaneously.
- (c) 604.2.15.1.3 Connected facilities. Power and lighting facilities for the fire command center and elevators specified in Sections 403.8 and 403.9 of the building code as listed in rule 1301:7-7-45 of the Administrative Code, as applicable, and electrically powered fire pumps required to maintain

*Note: for copyright claim information, please see the notice on the last page of this rule.*

pressure, shall be transferable to the standby source. Standby power shall be provided for at least one elevator to serve all floors and be transferable to any elevator.

- (ii) 604.2.15.2 Separate circuits and fixtures. Separate lighting circuits and fixtures shall be required to provide sufficient light with an intensity of not less than 1 foot-candle (11 lux) measured at floor level in all means of egress corridors, stairways, smokeproof enclosures, elevator cars and lobbies, and other areas which are clearly a part of the escape route.

(a) 604.2.15.2.1 Other circuits. Circuits supplying lighting for the fire command center and mechanical equipment rooms shall be transferable to the standby source.

- (iii) 604.2.15.3 Emergency systems. Exit signs, exit illumination as required by rule 1301:7-7-10 of the Administrative Code, and elevator car lighting are classified as emergency systems and shall operate within 10 seconds of failure of the normal power supply and shall be capable of being transferred to the standby source.

Exception: Exit sign, exit and means of egress illumination are permitted to be powered by a standby source in buildings of Group F and S occupancies.

- (p) 604.2.16 Underground buildings. Emergency and standby power systems in underground buildings covered in Chapter 4 of the building code as listed in rule 1301:7-7-45 of the Administrative Code shall comply with paragraphs (D)(2)(p)(i)(604.2.16.1) and (D)(2)(p)(ii)(604.2.16.2) of this rule.

- (i) 604.2.16.1 Standby power. A standby power system complying with the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code shall be provided for standby power loads as specified in paragraph (D)(2)(p)(i)(a)(604.2.16.1.1) of this rule.

(a) 604.2.16.1.1 Standby power loads. The following loads are classified as standby power loads:

(i) Smoke control system.

(ii) Ventilation and automatic fire detection equipment for

*Note: for copyright claim information, please see the notice on the last page of this rule.*

smokeproof enclosures.

(iii) Fire pumps.

(iv) Standby power shall be provided for elevators in accordance with Section 3003 of the building code as listed in rule 1301:7-7-45 of the Administrative Code.

(b) [B] 604.2.16.1.2 Pick-up time. The standby power system shall pick up its connected loads within 60 seconds of failure of the normal power supply.

(ii) 604.2.16.2 Emergency power. An emergency power system complying with the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code shall be provided for emergency power loads as specified in paragraph (D)(2)(p)(ii)(a)(604.2.16.2.1) of this rule.

(a) [B] 604.2.16.2.1 Emergency power loads. The following loads are classified as emergency power loads:

(i) Emergency voice/alarm communication systems.

(ii) Fire alarm systems.

(iii) Automatic fire detection systems.

(iv) Elevator car lighting.

(v) Means of egress lighting and exit sign illumination as required by rule 1301:7-7-10 of the Administrative Code.

(q) 604.2.17 Group I-3 occupancies. Power-operated sliding doors or power-operated locks for swinging doors in Group I-3 occupancies shall be operable by a manual release mechanism at the door, and either emergency power or a remote mechanical operating release shall be provided.

Exception: Emergency power is not required in facilities where provisions for remote locking and unlocking of occupied rooms in

*Note: for copyright claim information, please see the notice on the last page of this rule.*

Occupancy Condition 4 are not required as set forth in the building code as listed in rule 1301:7-7-45 of the Administrative Code.

- (r) 604.2.18 Airport traffic control towers. A standby power system shall be provided in airport traffic control towers more than 65 feet (19 812 mm) in height. Power shall be provided to the following equipment:
- (i) Pressurization equipment, mechanical equipment and lighting.
  - (ii) Elevator operating equipment.
  - (iii) Fire alarm and smoke detection systems.
- (s) 604.2.19 Elevators. In buildings and structures where standby power is required or furnished to operate an elevator, the operation shall be in accordance with paragraphs (D)(2)(s)(i)(604.2.19.1) to (D)(2)(s)(iv)(604.2.19.4) of this rule.
- (i) 604.2.19.1 Manual transfer. Standby power shall be manually transferable to all elevators in each bank.
  - (ii) 604.2.19.2 One elevator. Where only one elevator is installed, the elevator shall automatically transfer to standby power within 60 seconds after failure of normal power.
  - (iii) 604.2.19.3 Two or more elevators. Where two or more elevators are controlled by a common operating system, all elevators shall automatically transfer to standby power within 60 seconds after failure of normal power where the standby power source is of sufficient capacity to operate all elevators at the same time. Where the standby power source is not of sufficient capacity to operate all elevators at the same time, all elevators shall transfer to standby power in sequence, return to the designated landing and disconnect from the standby power source. After all elevators have been returned to the designated level, at least one elevator shall remain operable from the standby power source.
  - (iv) 604.2.19.4 Venting. Where standby power is connected to elevators, the machine room ventilation or air conditioning shall be connected to the standby power source.

*Note: for copyright claim information, please see the notice on the last page of this rule.*



- (3) 604.3 Maintenance. Emergency standby power systems shall be maintained in accordance with NFPA 110 and NFPA 111 as listed in rule 1301:7-7-45 of the Administrative Code such that the system is capable of supplying service within the time specified for the type and duration required.
- (a) 604.3.1 Schedule. Inspection, testing and maintenance of emergency and standby power systems shall be in accordance with an approved schedule established upon completion and approval of the system installation.
- (b) 604.3.2 Written record. Written records of the inspection, testing and maintenance of emergency and standby power systems shall include the date of service, name of the servicing technician, a summary of conditions noted and a detailed description of any conditions requiring correction and what corrective action was taken. Such records shall be kept on the premises served by the emergency or standby power system and be available for inspection by the fire code official.
- (c) 604.3.3 Switch maintenance. Emergency and standby power system transfer switches shall be included in the inspection, testing and maintenance schedule required by paragraph (D)(3)(a)(604.3.1) of this rule. Transfer switches shall be maintained free from accumulated dust and dirt. Inspection shall include examination of the transfer switch contacts for evidence of deterioration. When evidence of contact deterioration is detected, the contacts shall be replaced in accordance with the transfer switch manufacturer's instructions.
- (4) 604.4 Operational inspection and testing. Emergency power systems, including all appurtenant components shall be inspected and tested under load in accordance with NFPA 110 and NFPA 111 as listed in rule 1301:7-7-45 of the Administrative Code.
- Exception: Where the emergency power system is used for standby power or peak load shaving, such use shall be recorded and shall be allowed to be substituted for scheduled testing of the generator set, provided that appropriate records are maintained.
- (a) 604.4.1 Transfer switch test. The test of the transfer switch shall consist of electrically operating the transfer switch from the normal position to the alternate position and then return to the normal position.
- (5) 604.5 Supervision of maintenance and testing. Routine maintenance, inspection

*Note: for copyright claim information, please see the notice on the last page of this rule.*

and operational testing shall be overseen by a properly instructed individual.

(E) Section 605 Electrical equipment, wiring and hazards

(1) 605.1 Abatement of electrical hazards. Identified electrical hazards shall be abated. Identified hazardous electrical conditions in permanent wiring shall be brought to the attention of the code official responsible for enforcement of the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code. Electrical wiring, devices, appliances and other equipment that is modified or damaged and constitutes an electrical shock or fire hazard shall not be used.

(2) 605.2 Illumination. Illumination shall be provided for service equipment areas, motor control centers and electrical panelboards.

(3) 605.3 Working space and clearance. A working space of not less than 30 inches (762 mm) in width, 36 inches (914 mm) in depth and 78 inches (1981 mm) in height shall be provided in front of electrical service equipment. Where the electrical service equipment is wider than 30 inches (762 mm), the working space shall not be less than the width of the equipment. No storage of any materials shall be located within the designated working space.

Exceptions:

1. Where other dimensions are required or allowed by the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code.

2. Access openings into attics or under-floor areas which provide a minimum clear opening of 22 inches (559 mm) by 30 inches (762 mm).

(a) 605.3.1 Labeling. Doors into electrical control panel rooms shall be marked with a plainly visible and legible sign stating "ELECTRICAL ROOM" or similar approved wording. The disconnecting means for each service, feeder or branch circuit originating on a switchboard or panelboard shall be legibly and durably marked to indicate its purpose unless such purpose is clearly evident.

(4) 605.4 Multiplug adapters. Multiplug adapters, such as cube adapters, unfused plug strips or any other device not complying with the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code shall be prohibited.

(a) 605.4.1 Power tap design. Relocatable power taps shall be of the polarized

*Note: for copyright claim information, please see the notice on the last page of this rule.*

or grounded type, equipped with overcurrent protection, and shall be listed in accordance with UL 1363 as listed in rule 1301:7-7-45 of the Administrative Code.

- (b) 605.4.2 Power supply. Relocatable power taps shall be directly connected to a permanently installed receptacle.
- (c) 605.4.3 Installation. Relocatable power tap cords shall not extend through walls, ceilings, floors, under doors or floor coverings, or be subject to environmental or physical damage.
- (5) 605.5 Extension cords. Extension cords and flexible cords shall not be a substitute for permanent wiring. Extension cords and flexible cords shall not be affixed to structures, extended through walls, ceilings or floors, or under doors or floor coverings, nor shall such cords be subject to environmental damage or physical impact. Extension cords shall be used only with portable appliances.
  - (a) 605.5.1 Power supply. Extension cords shall be plugged directly into an approved receptacle, power tap or multiplug adapter and, except for approved multiplug extension cords, shall serve only one portable appliance.
  - (b) 605.5.2 Ampacity. The ampacity of the extension cords shall not be less than the rated capacity of the portable appliance supplied by the cord.
  - (c) 605.5.3 Maintenance. Extension cords shall be maintained in good condition without splices, deterioration or damage.
  - (d) 605.5.4 Grounding. Extension cords shall be grounded when serving grounded portable appliances.
- (6) 605.6 Unapproved conditions. Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes.
- (7) 605.7 Appliances. Electrical appliances and fixtures shall be tested and listed in published reports of inspected electrical equipment by an approved agency and installed and maintained in accordance with all instructions included as part of such listing.
- (8) 605.8 Electrical motors. Electrical motors shall be maintained free from

*Note: for copyright claim information, please see the notice on the last page of this rule.*

excessive accumulations of oil, dirt, waste and debris.

- (9) 605.9 Temporary wiring. Temporary wiring for electrical power and lighting installations is allowed for a period not to exceed 90 days. Temporary wiring methods shall meet the applicable provisions of the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code.

Exception: Temporary wiring for electrical power and lighting installations is allowed during periods of construction remodeling, repair or demolition of buildings, structures, equipment or similar activities.

- (a) 605.9.1 Attachment to structures. Temporary wiring attached to a structure shall be attached in an approved manner.

- (10) 605.10 Portable, electric space heaters. Portable, electric space heaters shall comply with paragraphs (E)(10)(a)(605.10.1) to (E)(10)(d)(605.10.4) of this rule.

- (a) 605.10.1 Listed and labeled. Only listed and labeled portable, electric space heaters shall be used.

- (b) 605.10.2 Power supply. Portable, electric space heaters shall be plugged directly into an approved receptacle.

- (c) 605.10.3 Extension cords. Portable, electric space heaters shall not be plugged into extension cords.

- (d) 605.10.4 Prohibited areas. Portable, electric space heaters shall not be operated within 3 feet (914 mm) of any combustible materials. Portable, electric space heaters shall be operated only in locations for which they are listed.

(F) Section 606 Mechanical refrigeration

- (1) [M] 606.1 Scope. Refrigeration systems shall be installed in accordance with the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code.

- (2) [M] 606.2 Refrigerants. The use and purity of new, recovered, and reclaimed refrigerants shall be in accordance with the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code.

*Note: for copyright claim information, please see the notice on the last page of this rule.*

- (3) [M] 606.3 Refrigerant classification. Refrigerants shall be classified in accordance with the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code.
- (4) [M] 606.4 Change in refrigerant type. A change in the type of refrigerant in a refrigeration system shall be in accordance with the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code.
- (5) 606.5 Access. Refrigeration systems having a refrigerant circuit containing more than 220 pounds (100 kg) of Group A1 or 30 pounds (14 kg) of any other group refrigerant shall be accessible to the fire department at all times as required by the fire code official.
- (6) 606.6 Testing of equipment. Refrigeration equipment and systems having a refrigerant circuit containing more than 220 pounds (100 kg) of Group A1 or 30 pounds (14 kg) of any other group refrigerant shall be subject to periodic testing in accordance with paragraph (F)(6)(a)(606.6.1) of this rule. A written record of required testing shall be maintained on the premises. Tests of emergency devices or systems required by this rule shall be conducted by persons trained and qualified in refrigeration systems.
- (a) 606.6.1 Periodic testing. The following emergency devices or systems shall be periodically tested in accordance with the manufacturer's instructions and as required by the fire code official.
- (i) Treatment and flaring systems.
  - (ii) Valves and appurtenances necessary to the operation of emergency refrigeration control boxes.
  - (iii) Fans and associated equipment intended to operate emergency ventilation systems.
  - (iv) Detection and alarm systems.
- (7) 606.7 Emergency signs. Refrigeration units or systems having a refrigeration circuit containing more than 220 pounds (100 kg) of Group A1 or 30 pounds (14 kg) of any other group refrigerant shall be provided with approved emergency signs, charts and labels in accordance with NFPA 704 as listed in rule 1301:7-7-45 of the Administrative Code. Hazard signs shall be in accordance with the mechanical code as listed in rule 1301:7-7-45 of the

*Note: for copyright claim information, please see the notice on the last page of this rule.*

Administrative Code for the classification of refrigerants listed therein.

- (8) 606.8 Refrigerant detector. Machinery rooms shall contain a refrigerant detector with an audible and visual alarm. The detector, or a sampling tube that draws air to the detector, shall be located in an area where refrigerant from a leak will concentrate. The alarm shall be actuated at a value not greater than the corresponding TLV-TWA values shown in the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code for the refrigerant classification. Detectors and alarms shall be placed in approved locations.
- (9) 606.9 Remote controls. Remote control of the mechanical equipment and appliances located in the machinery room shall be provided at an approved location immediately outside the machinery room and adjacent to its principal entrance.
- (a) 606.9.1 Refrigeration system. A clearly identified switch of the break-glass type shall provide off-only control of electrically energized equipment and appliances in the machinery room, other than refrigerant leak detectors and machinery room ventilation.
- Exception: In machinery rooms where only nonflammable refrigerants are used, electrical equipment and appliances, other than compressors, are not required to be provided with a cut-off switch.
- (b) 606.9.2 Ventilation system. A clearly identified switch of the break-glass type shall provide on-only control of the machinery room ventilation fans.
- (10) 606.10 Emergency pressure control system. Refrigeration systems containing more than 6.6 pounds (3 kg) of flammable, toxic or highly toxic refrigerant or ammonia shall be provided with an emergency pressure control system in accordance with paragraphs (F)(10)(a)(606.10.1) and (F)(10)(b)(606.10.2) of this rule.
- (a) 606.10.1 Automatic crossover valves. Each high- and intermediate-pressure zone in a refrigeration system shall be provided with a single automatic valve providing a crossover connection to a lower pressure zone. Automatic crossover valves shall comply with paragraphs (F)(10)(a)(i)(606.10.1.1) to (F)(10)(a)(iii)(606.10.1.3) of this rule.
- (i) 606.10.1.1 Overpressure limit setpoint. Automatic crossover valves shall be arranged to automatically relieve excess system pressure

*Note: for copyright claim information, please see the notice on the last page of this rule.*

to a lower pressure zone if the pressure in a high- or intermediate-pressure zone rises to within 15 psi (108.4 kPa) of the set point for emergency pressure-relief devices.

- (ii) 606.10.1.2 Manual operation. When required by the fire code official, automatic crossover valves shall be capable of manual operation.
  - (iii) 606.10.1.3 System design pressure. Refrigeration system zones that are connected to a higher pressure zone by an automatic crossover valve shall be designed to safely contain the maximum pressure that can be achieved by interconnection of the two zones.
- (b) 606.10.2 Automatic emergency stop. An automatic emergency stop feature shall be provided in accordance with paragraphs (F)(10)(b)(i)(606.10.2.1) and (F)(10)(b)(ii)(606.10.2.2) of this rule.
- (i) 606.10.2.1 Operation of an automatic crossover valve. Operation of an automatic crossover valve shall cause all compressors on the effected system to immediately stop. Dedicated pressure-sensing devices located immediately adjacent to crossover valves shall be permitted as a means for determining operation of a valve. To ensure that the automatic crossover valve system provides a redundant means of stopping compressors in an overpressure condition, high-pressure cutout sensors associated with compressors shall not be used as a basis for determining operation of a crossover valve.
  - (ii) 606.10.2.2 Overpressure in low-pressure zone. The lowest pressure zone in a refrigeration system shall be provided with a dedicated means of determining a rise in system pressure to within 15 psi (103.4 kPa) of the setpoint for emergency pressure-relief devices. Activation of the overpressure sensing device shall cause all compressors on the effected system to immediately stop.
- (11) 606.11 Storage, use and handling. Flammable and combustible materials shall not be stored in machinery rooms for refrigeration systems having a refrigerant circuit containing more than 220 pounds (100 kg) of Group A1 or 30 pounds (14 kg) of any other group refrigerant. Storage, use or handling of extra refrigerant or refrigerant oils shall be as required by rule 1301:7-7-27, rule 1301:7-7-30, rule 1301:7-7-32 and rule 1301:7-7-34 of the Administrative Code.

*Note: for copyright claim information, please see the notice on the last page of this rule.*

Exception: This provision shall not apply to spare parts, tools, and incidental materials necessary for the safe and proper operation and maintenance of the system.

(12) 606.12 Termination of relief devices. Pressure relief devices, fusible plugs and purge systems for refrigeration systems containing more than 6.6 pounds (3 kg) of flammable, toxic or highly toxic refrigerants shall be provided with an approved discharge system as required by paragraphs (F)(12)(a)(606.12.1), (F)(12)(b)(606.12.2) and (F)(12)(c)(606.12.3) of this rule. Discharge piping and devices connected to the discharge side of a fusible plug or rupture member shall have provisions to prevent plugging the pipe in the event of the fusible plug or rupture member functions.

(a) 606.12.1 Flammable refrigerants. Systems containing flammable refrigerants having a density equal to or greater than the density of air shall discharge vapor to the atmosphere only through an approved treatment system in accordance with paragraph (F)(12)(d)(606.12.4) of this rule or a flaring system in accordance with paragraph (F)(12)(e)(606.12.5) of this rule. Systems containing flammable refrigerants having a density of less than the density of air shall be permitted to discharge vapor to the atmosphere provided that the point of discharge is located outside of the structure at not less than 15 feet (4572 mm) above the adjoining grade level and not less than 20 feet (6096 mm) from any window, ventilation opening or exit.

(b) 606.12.2 Toxic and highly toxic refrigerants. Systems containing toxic or highly toxic refrigerants shall discharge vapor to the atmosphere only through an approved treatment system in accordance with paragraph (F)(12)(d)(606.12.4) of this rule or a flaring system in accordance with paragraph (F)(12)(e)(606.12.5) of this rule.

(c) 606.12.3 Ammonia refrigerant. Systems containing ammonia refrigerant shall discharge vapor to the atmosphere through an approved treatment system in accordance with paragraph (F)(12)(d)(606.12.4) of this rule, a flaring system in accordance with paragraph (F)(12)(e)(606.12.5) of this rule, or through an approved ammonia diffusion system in accordance with paragraph (F)(12)(f)(606.12.6) of this rule, or by other approved means.

Exceptions:

1. Ammonia/water absorption systems containing less than 22 pounds (10 kg) of ammonia and for which the ammonia circuit is located entirely outdoors.

*Note: for copyright claim information, please see the notice on the last page of this rule.*



2. When the fire code official determines, on review of an engineering analysis prepared in accordance with paragraph (D)(7)(b)(104.7.2) of rule 1301:7-7-01 of the Administrative Code, that a fire, health or environmental hazard would not result from discharging ammonia directly to the atmosphere.
- (d) 606.12.4 Treatment systems. Treatment systems shall be designed to reduce the allowable discharge concentration of the refrigerant gas to not more than 50 per cent of the IDLH at the point of exhaust. Treatment systems shall be in accordance with rule 1301:7-7-37 of the Administrative Code.
- (e) 606.12.5 Flaring systems. Flaring systems for incineration of flammable refrigerants shall be designed to incinerate the entire discharge. The products of refrigerant incineration shall not pose health or environmental hazards. Incineration shall be automatic upon initiation of discharge, shall be designed to prevent blowback, and shall not expose structures or materials to threat of fire. Standby fuel, such as LP gas, and standby power shall have the capacity to operate for one and one-half the required time for complete incineration of refrigerant in the system.
- (f) 606.12.6 Ammonia diffusion systems. Ammonia diffusion systems shall include a tank containing 1 gallon of water for each pound of ammonia (4 L of water for each 1 kg of ammonia) that will be released in 1 hour from the largest relief device connected to the discharge pipe. The water shall be prevented from freezing. The discharge pipe from the pressure relief device shall distribute ammonia in the bottom of the tank, but no lower than 33 feet (10 058 mm) below the maximum liquid level. The tank shall contain the volume of water and ammonia without overflowing.
- (13) 606.13 Discharge location for refrigeration machinery room ventilation. Exhaust from mechanical ventilation systems serving refrigeration machinery rooms capable of exceeding 25 per cent of the LFL or 50 per cent of the IDLH shall be equipped with approved treatment systems to reduce the discharge concentrations of flammable, toxic or highly toxic refrigerants to those values or lower.
- (14) 606.14 Notification of refrigerant discharges. The fire code official shall be notified immediately when a discharge becomes reportable under state, federal or local regulations in accordance with paragraph (C)(3)(a)(2703.3.1) of rule 1301:7-7-27 of the Administrative Code.

*Note: for copyright claim information, please see the notice on the last page of this rule.*

- (15) 606.15 Records. A written record shall be kept of refrigerant quantities brought into and removed from the premises. Such records shall be available to the fire code official.
- (16) 606.16 Electrical equipment. Where refrigerants of Groups A2, A3, B2, and B3, as defined in the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code, are used, refrigeration machinery rooms shall conform to the Class I, Division 2 hazardous location classification requirements of the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code.

Exception: Ammonia machinery rooms that are provided with ventilation in accordance with Section 1106.3 of the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code.

(G) Section 607 Elevator recall and maintenance

- (1) 607.1 Required. Existing elevators with a travel distance of 25 feet (7620 mm) or more above or below the main floor or other level of a building and intended to serve the needs of emergency personnel for fire-fighting or rescue purposes shall be provided with emergency operation in accordance with ASME A17.3 as listed in rule 1301:7-7-45 of the Administrative Code. New elevators shall be provided with Phase I emergency recall operation and Phase II emergency in-car operation in accordance with ASME A17.1 as listed in rule 1301:7-7-45 of the Administrative Code.
- (2) [B] 607.2 Emergency signs. An approved pictorial sign of a standardized design shall be posted adjacent to each elevator call station on all floors instructing occupants to use the exit stairways and not to use the elevators in case of fire. The sign shall read: "IN FIRE EMERGENCY, DO NOT USE ELEVATOR. USE EXIT STAIRS." The emergency sign shall not be required for elevators that are part of an accessible means of egress complying with paragraph (G)(4)(1007.4) of rule 1301:7-7-10 of the Administrative Code.
- (3) 607.3 Elevator keys. Keys for the elevator car doors and fire-fighter service keys shall be kept in an approved location for immediate use by the fire department.

(H) Section 608 Stationary storage battery systems

- (1) 608.1 Scope. Stationary storage battery systems having an electrolyte capacity of more than 50 gallons (189 L) for flooded lead acid, nickel cadmium

*Note: for copyright claim information, please see the notice on the last page of this rule.*

(Ni-Cd) and valve-regulated lead acid (VRLA), or 1,000 pounds (454 kg) for lithium-ion, used for facility standby power, emergency power, or uninterrupted power supplies shall comply with this paragraph and Table 608.1 of this rule.

Table 608.1 Battery requirements

Requirement	Nonrecombinant batteries		Recombinant batteries	
	Flooded nickel-cadmium (Ni-Cd) batteries	Valve regulated lead acid (VRLA) batteries	Lithium-ion batteries	
Safety caps	Venting caps (paragraph (H)(2)(a) (608.2.1) of this rule)	Venting caps (paragraph (H)(2)(a) (608.2.1) of this rule)	Self-resealing flame-arresting caps (paragraph (H)(2)(b) (608.2.2) of this rule)	No caps
Thermal runaway management	Not required	Not required	Required (paragraph (H)(3) (608.3) of this rule)	Not required
Spill control	Required (paragraph (H)(5) (608.5) of this rule)	Required (paragraph (H)(5) (608.5) of this rule)	Not required	Not required
Neutralization	Required (paragraph (H)(5)(a) (608.5.1) of this rule)	Required (paragraph (H)(5)(a) (608.5.1) of this rule)	Required (paragraph (H)(5)(b) (608.5.2) of this rule)	Not required
Ventilation	Required (paragraphs (H)(6)(a) (608.6.1); (H)(6)(b) (608.6.2) of this rule)	Required (paragraphs (H)(6)(a) (608.6.1); (H)(6)(b) (608.6.2) of this rule)	Required (paragraphs (H)(6)(a) (608.6.1); (H)(6)(b) (608.6.2) of this rule)	Not required
Signage	Required (paragraph	Required (paragraph	Required (paragraph	Required (paragraph

*Note: for copyright claim information, please see the notice on the last page of this rule.*

	(H)(7) (608.7) of this rule)	(H)(7) (608.7) of this rule)	(H)(7) (608.7) of this rule)	(H)(7) (608.7) of this rule)
Seismic protection	Required (paragraph (H)(8) (608.8) of this rule)	Required (paragraph (H)(8) (608.8) of this rule)	Required (paragraph (H)(8) (608.8) of this rule)	Required (paragraph (H)(8) (608.8) of this rule)
Smoke detection	Required (paragraph (H)(9) (608.9) of this rule)	Required (paragraph (H)(9) (608.9) of this rule)	Required (paragraph (H)(9) (608.9) of this rule)	Required (paragraph (H)(9) (608.9) of this rule)

- (2) 608.2 Safety caps. Safety caps for stationary storage battery systems shall comply with paragraphs (H)(2)(a)(608.2.1) and (H)(2)(b)(608.2.2) of this rule.
- (a) 608.2.1 Nonrecombinant batteries. Vented lead acid, nickel-cadmium or other types of nonrecombinant batteries shall be provided with safety venting caps.
- (b) 608.2.2 Recombinant batteries. VRLA batteries shall be equipped with self-resealing flame-arresting safety vents.
- (3) 608.3 Thermal runaway. VRLA battery systems shall be provided with a listed device or other approved method to preclude, detect and control thermal runaway.
- (4) 608.4 Room design and construction. Enclosure of stationary battery systems shall comply with the building code as listed in rule 1301:7-7-45 of the Administrative Code. Battery systems shall be allowed to be in the same room with the equipment they support.
- (a) 608.4.1 Separate rooms. When stationary batteries are installed in a separate equipment room accessible only to authorized personnel, they shall be permitted to be installed on an open rack for ease of maintenance.
- (b) 608.4.2 Occupied work centers. When a system of VRLA, lithium-ion, or other type of sealed, nonventing batteries is situated in an occupied work center, it shall be allowed to be housed in a noncombustible cabinet or other enclosure to prevent access by unauthorized personnel.

*Note: for copyright claim information, please see the notice on the last page of this rule.*

(c) 608.4.3 Cabinets. When stationary batteries are contained in cabinets in occupied work centers, the cabinet enclosures shall be located within 10 feet (3048 mm) of the equipment that they support.

(5) 608.5 Spill control and neutralization. An approved method and materials for the control and neutralization of a spill of electrolyte shall be provided in areas containing lead-acid, nickel-cadmium or other types of batteries with free-flowing liquid electrolyte. For purposes of this paragraph, a "spill" is defined as any unintentional release of electrolyte.

Exception: VRLA, lithium-ion or other types of sealed batteries with immobilized electrolyte shall not require spill control.

(a) 608.5.1 Nonrecombinant battery neutralization. For battery systems containing lead-acid, nickel-cadmium or other types of batteries with free-flowing electrolyte, the method and materials shall be capable of neutralizing a spill from the largest lead-acid battery to a pH between 7.0 and 9.0.

(b) 608.5.2 Recombinant battery neutralization. For VRLA or other types of sealed batteries with immobilized electrolyte, the method and material shall be capable of neutralizing a spill of 3 per cent of the capacity of the largest VRLA cell or block in the room to a pH between 7.0 and 9.0.

Exception: Lithium-ion batteries shall not require neutralization.

(6) 608.6 Ventilation. Ventilation of stationary and storage battery systems shall comply with paragraphs (H)(6)(a)(608.6.1) and (H)(6)(b)(608.6.2) of this rule.

(a) 608.6.1 Room ventilation. Ventilation shall be provided in accordance with the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code and the following:

(i) For flooded lead acid, flooded nickel-cadmium, and VRLA batteries, the ventilation system shall be designed to limit the maximum concentration of hydrogen to 1 per cent of the total volume of the room; or

(ii) Continuous ventilation shall be provided at a rate of not less than 1 cubic foot per minute per square foot [1 ft<sup>3</sup>/min/ft<sup>2</sup> or 0.0051

*Note: for copyright claim information, please see the notice on the last page of this rule.*

m<sup>3</sup>/(s.m<sup>2</sup>)] of floor area of the room.

Exception: Lithium-ion batteries shall not require ventilation.

- (b) 608.6.2 Cabinet ventilation. When VRLA batteries are installed inside a cabinet, the cabinet shall be approved for use in occupied spaces and shall be mechanically or naturally vented by one of the following methods:
- (i) The cabinet ventilation shall limit the maximum concentration of hydrogen to 1 per cent of the total volume of the cabinet during the worst-case event of simultaneous "boost" charging of all the batteries in the cabinet; or
  - (ii) When calculations are not available to substantiate the ventilation rate, continuous ventilation shall be provided at a rate of not less than 1 cubic foot per minute per square foot [1 ft<sup>3</sup>/min/ft<sup>2</sup> or 0.0051 m<sup>3</sup>/(s.m<sup>2</sup>)] of the floor area covered by the cabinet. The room in which the cabinet is installed shall also be ventilated as required in paragraph (H)(6)(a)(608.6.1) of this rule.
- (7) 608.7 Signage. Signs shall comply with paragraphs (H)(7)(a)(608.7.1) and (H)(7)(b)(608.7.2) of this rule.
- (a) 608.7.1 Equipment room and building signage. Doors into electrical equipment rooms or buildings containing stationary battery systems shall be provided with approved signs. The signs shall state that:
    - (i) The room contains energized battery systems.
    - (ii) The room contains energized electrical circuits.
    - (iii) The battery electrolyte solutions, where present, are corrosive liquids.
  - (b) 608.7.2 Cabinet signage. Cabinets shall have exterior labels that identify the manufacturer and model number of the system and electrical rating (voltage and current) of the contained battery system. There shall be signs within the cabinet that indicate the relevant electrical, chemical and fire hazards.

- (8) 608.8 Seismic protection. The battery systems shall be seismically braced in


*Note: for copyright claim information, please see the notice on the last page of this rule.*

accordance with the building code as listed in rule 1301:7-7-45 of the Administrative Code.

- (9) 608.9 Smoke detection. An approved automatic smoke detection system shall be installed in accordance with paragraph (G)(2)(907.2) of rule 1301:7-7-09 of the Administrative Code in rooms containing stationary battery systems.

(I) [M] Section 609 Commercial kitchen hoods

- (1) [M] 609.1 General. Commercial kitchen exhaust hoods shall comply with the requirements of the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code.
- (2) [M] 609.2 Where required. A Type I hood shall be installed at or above all commercial cooking appliances and domestic cooking appliances used for commercial purposes that produce grease vapors.



Effective:

R.C. 119.032 review dates: 05/18/2011

---

Certification

---

Date

Promulgated Under: 119.03  
Statutory Authority: 3737.82, 3737.86  
Rule Amplifies: N/A  
Prior Effective Dates: 7/1/79, 6/1/85, 6/15/92, 7/1/93, 9/1/95, 3/30/98,  
1/3/00, 9/1/05, 7/1/07

Copyright Claim Information

The Ohio Fire Code ("OFC") designates and incorporates substantial portions of the ICC INTERNATIONAL FIRE CODE/2003, a copyrighted work owned by the International Code Council. The International Code Council, Inc., Falls Church, Virginia ("ICC") asserts a copyright in those portions of the OFC based upon the International Fire Code/2003.

The ICC asserts that no part of the International Fire Code/2003, as an independent document, may be reproduced, distributed, or transmitted in any form or by any means, including, without limitation, electronic, optical, or mechanical means (by way of example, and not limitation, photocopying, or recording by or in an information storage and retrieval system) without its advance written permission. For information on permission to copy material from the IFC exceeding fair use, please contact: International Code Council, Attn: ICC General Counsel, Birmingham Regional Office, 900 Montclair Road, Birmingham, AL 35213-1206.