

1301:7-7-07**Fire-resistance-rated construction.**(A) Section 701 General

- (1) 701.1 Scope. The provisions of this rule shall specify the requirements for and the maintenance of fire-resistance-rated construction and requirements for enclosing floor openings and shafts in existing buildings. New construction shall comply with the building code as listed in rule 1301:7-7-45 of the Administrative Code.

(B) Section 702 Definitions

- (1) 702.1 Terms defined in rule 1301:7-7-02 of the Administrative Code. Words and terms used in this rule and defined in rule 1301:7-7-02 of the Administrative Code shall have the meanings ascribed to them as defined therein.

(C) Section 703 Fire-resistance-rated construction

- (1) 703.1 Maintenance. The required fire-resistance rating of fire-resistance-rated construction (including walls, fire stops, shaft enclosures, partitions and floors) shall be maintained. Such elements shall be properly repaired, restored or replaced when damaged, altered, breached or penetrated. Openings made therein for the passage of pipes, electrical conduit, wires, ducts, air transfer openings, and holes made for any reason shall be protected with approved methods capable of resisting the passage of smoke and fire. Openings through fire-resistance-rated assemblies shall be protected by self-closing or automatic-closing doors of approved construction meeting the fire protection requirements for the assembly.

(a) 703.1.1 Fireblocking and draftstopping. Required fireblocking and draftstopping in combustibles concealed spaces shall be maintained to provide continuity and integrity of the construction.

(b) 703.1.2 Smoke barriers. Required smoke barrier partitions shall be maintained to prevent the passage of smoke and all openings protected with approved smoke barrier doors or leakage-rated (smoke) dampers.

- (2) 703.2 Opening protectives. Opening protectives shall be maintained in an operative condition in accordance with NFPA 80 as listed in rule 1301:7-7-45 of the Administrative Code. Fire doors and smoke barrier doors shall not be blocked or obstructed or otherwise made inoperable. Fusible links shall be replaced promptly whenever fused or damaged. Fire door assemblies shall not be modified.

(a) 703.2.1 Signs. Where required by the fire code official, a sign shall be permanently displayed on or near each fire door in letters not less than 1 inch (25 mm) high to read as follows:

*Note: for copyright claim information, please see the notice on the last page of this rule.*

(i) For doors designed to be kept normally open: FIRE DOOR - DO NOT BLOCK.

(ii) For doors designed to be kept normally closed: FIRE DOOR - KEEP CLOSED.

(b) 703.2.2 Hold-open devices and closers. Hold-open devices and automatic door closers, where provided, shall be maintained. During the period that such device is out of service for repairs, the door it operates shall remain in the closed position.

(c) 703.2.3 Door operation. Swinging fire doors shall close from the full-open position and latch automatically. The door closer shall exert enough force to close and latch the door from any partially open position.

(3) 703.3 Ceilings. The hanging and displaying of salable goods and other decorative materials from acoustical ceiling systems that are part of a fire-resistance-rated floor/ceiling or roof/ceiling assembly, shall be prohibited.

(4) 703.4 Testing. Horizontal and vertical sliding and rolling fire doors shall be inspected and tested annually to confirm proper operation and full closure. A written record shall be maintained and be available to the fire code official.

(D) Section 704 Floor openings and shafts

(1) 704.1 Enclosure. Interior vertical shafts, including but not limited to stairways, elevator hoistways, service and utility shafts, that connect two or more stories of a building shall be enclosed or protected as specified in Table 704.1 of this rule. When openings are required to be protected, openings into such shafts shall be maintained self-closing or automatic-closing by smoke detection. Existing fusible-link-type automatic door-closing devices are permitted if the fusible link rating does not exceed 135°F (57°C).

Table 704.1 Vertical opening protection required

<u>Occupancy classification</u>	<u>Conditions</u>	<u>Protection required</u>
<u>Group I</u>	<u>Vertical openings connecting two or more stories</u>	<u>1-hour protection</u>
<u>All, other than Group I</u>	<u>Vertical openings connecting two stories</u>	<u>No protection required<sup>a,b</sup></u>
<u>All, other than Group I</u>	<u>Vertical openings connecting three to five</u>	<u>1-hour protection or automatic sprinklers</u>

*Note: for copyright claim information, please see the notice on the last page of this rule.*

	<u>stories</u>	<u>throughout</u> <sup>a,b</sup>
<u>All, other than Group I</u>	<u>Vertical openings connecting more than five stories</u>	<u>1-hour protection</u> <sup>a,b</sup>
<u>All</u>	<u>Mezzanines open to the floor below</u>	<u>No protection required</u> <sup>a,b</sup>
<u>All, other than Group I</u>	<u>Atriums and covered mall buildings</u>	<u>1-hour protection or automatic sprinklers throughout</u>
<u>All, other than Groups B and M</u>	<u>Escalator openings connecting four or less stories in a sprinklered building. Openings must be protected by a draft curtain and closely spaced sprinklers in accordance with NFPA 13 as listed in rule 1301:7-7-45 of the Administrative Code.</u>	<u>No protection required</u>
<u>Group B and M</u>	<u>Escalator openings in a sprinklered building protected by a draft curtain and closely spaced sprinklers in accordance with NFPA 13 as listed in rule 1301:7-7-45 of the Administrative Code.</u>	<u>No protection required</u>

a. Vertical opening protection is not required for Group R-3 occupancies.

b. Vertical opening protection is not required for open parking garages and ramps.

*Note: for copyright claim information, please see the notice on the last page of this rule.*

Replaces: 1301:7-7-03

Effective:

R.C. 119.032 review dates:

---

Certification

---

Date

Promulgated Under: 119.03  
Statutory Authority: 3737.22, 3737.82  
Rule Amplifies: 3737.22, 3737.82  
Prior Effective Dates: 7/1/79, 6/1/85, 6/15/92, 7/1/93, 9/1/95, 1/9/98,  
11/20/98

#### Copyright Claim Information

The Ohio Fire Code ("OFC") designates and incorporates substantial portions of the ICC INTERNATIONAL FIRE CODE/2003, a copyrighted work owned by the International Code Council. The International Code Council, Inc., Falls Church, Virginia ("ICC") asserts a copyright in those portions of the OFC based upon the International Fire Code/2003.

The ICC asserts that no part of the International Fire Code/2003, as an independent document, may be reproduced, distributed, or transmitted in any form or by any means, including, without limitation, electronic, optical, or mechanical means (by way of example, and not limitation, photocopying, or recording by or in an information storage and retrieval system) without its advance written permission. For information on permission to copy material from the IFC exceeding fair use, please contact: International Code Council, Attn: ICC General Counsel, Birmingham Regional Office, 900 Montclair Road, Birmingham, AL 35213-1206.