

To Be Rescinded

1301:7-7-11 Dry cleaning plants.

(A) Section FM-1101.0 General

(1) FM-1101.1 Scope: All dry cleaning plants shall comply with this rule.

(2) F-1101.2 ~~Permit~~APPROVAL required: A person shall not operate a dry cleaning plant without first obtaining a ~~permit~~APPROVAL from the code official. The ~~permit~~APPROVAL shall prescribe the type of dry cleaning system to be utilized.

(B) Section FM-1102.0 Definitions

FM-1102.1 General: The following words and terms shall, for the purposes of this rule and as stated elsewhere in this code, have the meanings shown herein.

Dry cleaning: The process of removing dirt, grease, paint and other stains from materials such as wearing apparel, textiles, fabrics and rugs, by the use of solvents. Methods of dry cleaning include:

- (1) Immersion and agitation with the solvent in closed machines;;
- (2) Brushing or scouring with a cleaning solvent;; and
- (3) Dual-phase processing.

Dry cleaning plant: A plant in which dry cleaning and associated operations are conducted, including office, receiving and storage rooms.

Dual-phase processing: A process in which the dry cleaning operation precedes or follows, or precedes and follows, a laundering operation in the same equipment.

Types of dry cleaning plants or systems: Dry cleaning plants or systems are arranged in the following types:

Type I - Systems employing class I solvents

Type II - Systems employing class II solvents

Type IIIA - Systems employing class IIIA solvents

Type IIIB - Systems employing class IIIB solvents

Type IV - Systems employing class IV solvents

Type V - Systems employing class IV solvents and in which the dry cleaning is conducted by the public.

(C) Section FM-1103.0 General requirements

(1) FM-1103.1 General: The equipment, processes and operation of dry cleaning plants shall comply with the building, mechanical and plumbing codes listed in rule 1301:7-7-44 of the Administrative Code.

(2) FM-1103.2 Operation and maintenance: The operation and maintenance of all dry cleaning plants shall be conducted in accordance with NFPA 32 listed in rule 1301:7-7-44 of the Administrative Code.

(3) F-1103.3 Multiclass solvents: Dry cleaning plants employing more than one class of solvent for dry cleaning shall comply with the requirements for the numerically lowest class of solvent employed.

(4) F-1103.4 Change in solvent: Written consent shall be obtained from the code official before changing the solvent to a more hazardous class.

(5) F-1103.5 Solvent type: The use of solvents with a flash point below that for which a machine is designed shall be prohibited.

(6) F-1103.6 Prohibited plants: Type I dry cleaning plants or systems shall be prohibited.

(D) Section F-1104.0 Fire safety requirements


(1) F-1104.1 Portable fire extinguishers: At least one portable fire extinguisher with a minimum 2-A:20-B:C rating shall be provided within 75 feet (22860 mm) of travel distance in all dry cleaning plants.

(2) F-1104.2 Additional extinguishers: At least two portable fire extinguishers with a minimum 40-B:C rating shall be located within 30 feet (9144 mm) of travel distance inside a dry cleaning room, near the egress doors.

Exception: Types IV and V dry cleaning plants.

1301:7-7-11

Effective: March 30, 1998



Certification

March 12, 1998

Date

Promulgated under:	R.C. Section 119.03
Rule amplifies:	R.C. Section 3737.22
Authorized by:	R.C. Section 3737.82
R.C. 119.032 Review Date:	1/01/03
Prior effective date:	7/01/79;6/01/85;6/15/92;7/1/93;9/1/95

Effective:

R.C. 119.032 review dates: 11/23/2004

WITHDRAWN ELECTRONICALLY

Certification

06/10/2005

Date

Promulgated Under:	119.03
Statutory Authority:	3737.82, 3737.86
Rule Amplifies:	N/A
Prior Effective Dates:	7/1/79, 6/1/85, 6/15/92, 7/1/93, 9/1/95