

1301:7-7-12**Dry cleaning.****(A) Section 1201 General**

- (1) 1201.1 Scope. Dry cleaning plans and their operations shall comply with the requirements of this rule.
- (2) 1201.2 Permit required. Permits shall be required as set forth in paragraph (E)(6)(105.6) of rule 1301:7-7-01 of the Administrative Code.

(B) Section 1202 Definitions

- (1) 1202.1 Definitions. The following words and terms shall, for the purposes of this rule and as used elsewhere in this code, have the meanings shown herein.

"Dry cleaning." The process of removing dirt, grease, paints and other stains from such items as wearing apparel, textiles, fabrics and rugs by use of nonaqueous liquids (solvents).

"Dry cleaning plant." A facility in which dry cleaning and associated operations are conducted, including the office, receiving area and storage rooms.

"Dry cleaning room." An occupiable space within a building used for performing dry cleaning operations, the installation of solvent-handling equipment or the storage of dry cleaning solvents.

"Dry cleaning system." Machinery or equipment in which textiles are immersed or agitated in solvent or in which dry cleaning solvent is extracted from textiles.

"Solvent or liquid classifications." A method for classifying solvents or liquids according to the following classes:

"Class I solvents." Liquids having a flash point below 100°F (38°C).

"Class II solvents." Liquids having a flash point at or above 100°F (38°C) and below 140°F (60°C).

"Class IIIA solvents." Liquids having a flash point at or above 140°F (60°C) and below 200°F (93°C).

"Class IIIB solvents." Liquids having a flash point at or above 200°F (93°C).

"Class IV solvents." Liquids classified as nonflammable.

(C) Section 1203 Classifications

Note: for copyright claim information, please see the notice on the last page of this rule.

(1) 1203.1 Solvent classifications. Dry cleaning solvents shall be classified according to their flash points as follows:

(a) Class I solvents are liquids having a flash point below 100°F (38°C).

(b) Class II solvents are liquids having a flash point at or above 100°F (38°C) and below 140°F (60°C).

(c) Class IIIA solvents are liquids having a flash point at or above 140°F (60°C) and below 200°F (93°C).

(d) Class IIIB solvents are liquids having a flash point at or above 200°F (93°C).

(e) Class IV solvents are liquids classified as nonflammable.

(2) 1203.2 Classification of dry cleaning plants and systems. Dry cleaning plants and systems shall be classified based on the solvents used as follows:

(a) Type I-systems using Class I solvents.

(b) Type II-systems using Class II solvents.

(c) Type III-A-systems using Class IIIA solvents.

(d) Type III-B-systems using Class IIIB solvents.

(e) Type IV-systems using Class IV solvents in which dry cleaning is not conducted by the public.

(f) Type V-systems using Class IV solvents in which dry cleaning is conducted by the public.

Spotting and pretreating operations conducted in accordance with paragraph (F)(1206) of this rule shall not change the type of the dry cleaning plant.

(i) 1203.2.1 Multiple solvents. Drying cleaning plants using more than one class of solvent for dry cleaning shall be classified based on the numerically lowest solvent class.

(3) 1203.3 Design. The occupancy classification, design and construction of dry cleaning plants shall comply with the applicable requirements of the building code listed in rule 1301:7-7-45 of the Administrative Code.

(D) Section 1204 General requirements

Note: for copyright claim information, please see the notice on the last page of this rule.

- (1) 1204.1 Prohibited use. Type I dry cleaning plants shall be prohibited. Limited quantities of Class I solvents stored and used in accordance with this paragraph shall not be prohibited in dry cleaning plants.
- (2) 1204.2 Building services. Building services and systems shall be designed, installed and maintained in accordance with this paragraph and rule 1301:7-7-06 of the Administrative Code.
- (a) 1204.2.1 Ventilation. Ventilation shall be provided in accordance with Section 502 of the mechanical code and DOL 29 CFR Part 1910.1000 as listed in rule 1301:7-7-45 of the Administrative Code, where applicable.
- (b) 1204.2.2 Heating. In Type II dry cleaning plants, heating shall be by indirect means using steam, hot water, or hot oil only.
- (c) 1204.2.3 Electrical wiring and equipment. Electrical wiring and equipment in dry cleaning rooms or other locations subject to flammable vapors shall be installed in accordance with the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code.
- (d) 1204.2.4 Bonding and grounding. Storage tanks, treatment tanks, filters, pumps, piping, ducts, dry cleaning units, stills, tumblers, drying cabinets and other such equipment, where not inherently electrically conductive, shall be bonded together and grounded. Isolated equipment shall be grounded.
- (E) Section 1205 Operating requirements
- (1) 1205.1 General. The operation of dry cleaning systems shall comply with the requirements of this paragraph.
- (a) 1205.1.1 Written instructions. Written instructions covering the proper installation and safe operation and use of equipment and solvent shall be given to the buyer.
- (i) 1205.1.1.1 Type II, III-A, III-B and IV systems. In Type II, III-A, III-B and IV dry cleaning systems, machines shall be operated in accordance with the operating instructions furnished by the machinery manufacturer. Employees shall be instructed as to the hazards involved in their departments and in the work they perform.
- (ii) 1205.1.1.2 Type V systems. Operating instructions for customer use of Type V dry cleaning systems shall be conspicuously posted in

Note: for copyright claim information, please see the notice on the last page of this rule.

a location near the dry cleaning unit. A telephone number shall be provided for emergency assistance.

(b) 1205.1.2 Equipment identification. The manufacturer shall provide nameplates on dry cleaning machines indicating the class of solvent for which each machine is designed.

(c) 1205.1.3 Open systems prohibited. Dry cleaning by immersion and agitation in open vessels shall be prohibited.

(d) 1205.1.4 Prohibited use of solvent. The use of solvents with a flash point below that for which a machine is designed or listed shall be prohibited.

(e) 1205.1.5 Equipment maintenance and housekeeping. Proper maintenance and operating practices shall be observed in order to prevent the leakage of solvent or the accumulation of lint. The handling of waste material generated by dry cleaning operations and the maintenance of facilities shall comply with the provisions of this paragraph.

(i) 1205.1.5.1 Floors. Class I and II liquids shall not be used for cleaning floors.

(ii) 1205.1.5.2 Filters. Filter residue and other residues containing solvent shall be handled and disposed of in covered metal containers.

(iii) 1205.1.5.3 Lint. Lint and refuse shall be removed from traps daily, deposited in approved waste cans, removed from the premises, and disposed of safely. At all other times, traps shall be held securely in place.

(iv) 1205.1.5.4 Customer areas. In Type V dry cleaning system, customer areas shall be kept clean.

(2) 1205.2 Type II systems. Special operating requirements for Type II dry cleaning systems shall comply with the provisions of this paragraph.

(a) 1205.2.1 Inspection of materials. Materials to be dry cleaned shall be searched thoroughly and foreign materials, including matches and metallic substances, shall be removed.

(b) 1205.2.2 Material transfer. In removing materials from the washer, provisions shall be made for minimizing the dripping of solvent on the floor. Where materials are transferred from a washer to a drain tub, a nonferrous metal drip apron shall be placed so that the apron rests on the drain tub and the cylinder of the washer.

Note: for copyright claim information, please see the notice on the last page of this rule.

(c) 1205.2.3 Ventilation. A mechanical ventilation system which is designed to exhaust 1 cubic foot of air per minute for each square foot of floor area [0.0058 m³/(s·m²)] shall be installed in dry cleaning rooms and in drying rooms. The ventilation system shall operate when the dry cleaning equipment is in operation and shall have manual controls at an approved location.

(3) 1205.3 Type IV and V systems. Type IV and V dry cleaning systems shall be provided with an automatically activated exhaust ventilation system to maintain a minimum of 100 feet per minute (51 m/s) air velocity through the loading door when the door is opened. Such systems for dry cleaning equipment shall comply with the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code.

Exception: Dry cleaning units are not required to be provided with exhaust ventilation where an exhaust hood is installed immediately outside of and above the loading door which operates at an airflow rate as follows:

$$Q = 100 \times A_{LD} \text{ (Equation 12-1)}$$

where:

Q=flow rate exhausted through the hood, cubic feet per minute (m³/s).

A_{LD} ≡ area of the loading door, square feet (m²).

(F) Section 1206 Spotting and pretreating

(1) 1206.1 General. Spotting and pretreating operations and equipment shall comply with the provisions of this paragraph.

(2) 1206.2 Type I solvents. The maximum quantity of Type I solvents permitted at any work station shall be 1 gallon (4 L). Class I solvents shall be stored in approved safety cans or in sealed DOTn-approved metal shipping containers of not more than 1-gallon (4 L) capacity. Dispensing shall be from approved safety cans.

(3) 1206.3 Type II and III solvents. Scouring, brushing, and spotting and pretreating shall be conducted with Class II or III solvents. The maximum quantity of Type II or III solvents permitted at any work station shall be 1 gallon (4 L). In other than a Group H-2 occupancy, the aggregate quantities of solvents shall not exceed the maximum allowable quantity per control area for use-open system.

(a) 1206.3.1 Spotting tables. Scouring, brushing or spotting tables on which articles are soaked in solvent shall have a liquid-tight top with a curb on

Note: for copyright claim information, please see the notice on the last page of this rule.

all sides not less than 1 inch (25 mm) high. The top of the table shall be pitched to ensure thorough draining to a 1.5-inch (38 mm) drain connected to an approved container.

(b) 1206.3.2 Special handling. When approved, articles that cannot be washed in the usual washing machines are allowed to be cleaned in scrubbing tubs. Scrubbing tubs shall comply with the following:

(i) Only Class II or III liquids shall be used.

(ii) The total amount of solvent used in such open containers shall not exceed 3 gallons (11 L).

(iii) Scrubbing tubs shall be secured to the floor.

(iv) Scrubbing tubs shall be provided with permanent 1.5-inch (38 mm) drains. Such drain shall be provided with a trap and shall be connected to an approved container.

(c) 1206.3.3 Ventilation. Scrubbing tubs, scouring, brushing or spotting operations shall be located such that solvent vapors are captured and exhausted by the ventilating system.

(d) 1206.3.4 Bonding and grounding. Metal scouring, brushing and spotting tables and scrubbing tubs shall be permanently and effectively bonded and grounded.

(4) 1206.4 Type IV systems. Flammable and combustible liquids used for spotting operations shall be stored in approved safety cans or in sealed DOTn-approved metal shipping containers of not more than 1 gallon (4 L) in capacity. Dispensing shall be from approved safety cans. Aggregate amounts shall not exceed 10 gallons (38 L).

(5) 1206.5 Type V systems. Spotting operations using flammable or combustible liquids are prohibited in Type V dry cleaning systems.

(G) Section 1207 Dry cleaning systems

(1) 1207.1 General equipment requirements. Dry cleaning systems, including dry cleaning units, washing machines, stills, drying cabinets, tumblers, and their appurtenances, including pumps, piping, valves, filters and solvent coolers, shall be installed and maintained in accordance with NFPA 32 as listed in rule 1301:7-7-45 of the Administrative Code. The construction of the buildings in which such systems are located shall comply with the requirements of this paragraph and the building code listed in rule 1301:7-7-45 of the Administrative Code. B:C portable fire extinguishers shall be provided near the doors inside dry cleaning rooms containing Type II,

Note: for copyright claim information, please see the notice on the last page of this rule.

Type III-A and Type III-B dry cleaning systems.

- (2) 1207.2 Type II systems. Type II dry cleaning and solvent tank storage rooms shall not be located below grade or above the lowest floor level of the building and shall comply with paragraphs (G)(2)(a)(1207.2.1) to (G)(2)(c)(1207.2.3) of this rule.

Exception: Solvent storage tanks installed underground, in vaults or in special enclosures in accordance with rule 1301:7-7-34 of the Administrative Code.

- (a) 1207.2.1 Fire-fighting access. Type II dry cleaning plants shall be located so that access is provided and maintained from one side for fire-fighting and fire control purposes in accordance with paragraph (C)(503) of rule 1301:7-7-05 of the Administrative Code.

- (b) 1207.2.2 Number of means of egress. Type II dry cleaning rooms shall have not less than two means of egress doors located at opposite ends of the room, at least one of which shall lead directly to the outside.

- (c) 1207.2.3 Spill control and secondary containment. Curbs, drains, or other provisions for spill control and secondary containment shall be provided in accordance with paragraph (D)(2)(2704.2) of rule 1301:7-7-27 of the Administrative Code to collect solvent leakage and fire protection water and direct it to a safe location.

- (3) 1207.3 Solvent storage tanks. Solvent storage tanks for Class II, IIIA and IIIB liquids shall conform to the requirements of rule 1301:7-7-34 of the Administrative Code and be located underground or outside, above ground.

Exception: As provided in NFPA 32 as listed in rule 1301:7-7-45 of the Administrative Code for inside storage or treatment tanks.

(H) Section 1208 Fire protection

- (1) 1208.1 General. Where required by this paragraph, fire protection systems, devices and equipment shall be installed, inspected, tested and maintained in accordance with rule 1301:7-7-09 of the Administrative Code.

- (2) 1208.2 Automatic sprinkler system. An automatic sprinkler system shall be installed in accordance with paragraph (C)(3)(a)(i)(903.3.1.1) of rule 1301:7-7-09 of the Administrative Code throughout dry cleaning plants containing Type II, Type III-A or Type III-B dry cleaning systems.

- (3) 1208.3 Automatic fire-extinguishing systems. Type II dry cleaning units, washer-extractors, and drying tumblers in Type II dry cleaning plants shall be provided with an approved automatic fire-extinguishing system installed and maintained in accordance with rule 1301:7-7-09 of the Administrative Code.

Note: for copyright claim information, please see the notice on the last page of this rule.

Exception: Where approved, a manual steam jet not less than 0.75 inch (19 mm) with a continuously available steam supply at a pressure not less than 15 pounds per square inch gauge (psig) (103 kPa) is allowed to be substituted for the automatic fire-extinguishing system.

- (4) 1208.4 Portable fire extinguishers. Portable fire extinguishers shall be selected, installed and maintained in accordance with this paragraph and paragraph (F)(906) of rule 1301:7-7-09 of the Administrative Code. A minimum of two 2-A:10-B:C portable fire extinguishers shall be provided near the doors inside dry cleaning rooms containing Type II, Type III-A and Type III-B dry cleaning systems.



Note: for copyright claim information, please see the notice on the last page of this rule.

Replaces: 1301:7-7-11

Effective:

R.C. 119.032 review dates:

WITHDRAWN ELECTRONICALLY

Certification

06/10/2005

Date

Promulgated Under: 119.03
Statutory Authority: 3737.22, 3737.82
Rule Amplifies: 3737.22, 3737.82
Prior Effective Dates: 7/1/79, 6/1/85, 6/15/92, 7/1/95, 9/1/95, 3/30/98

Copyright Claim Information

The Ohio Fire Code ("OFC") designates and incorporates substantial portions of the ICC INTERNATIONAL FIRE CODE/2003, a copyrighted work owned by the International Code Council. The International Code Council, Inc., Falls Church, Virginia ("ICC") asserts a copyright in those portions of the OFC based upon the International Fire Code/2003.

The ICC asserts that no part of the International Fire Code/2003, as an independent document, may be reproduced, distributed, or transmitted in any form or by any means, including, without limitation, electronic, optical, or mechanical means (by way of example, and not limitation, photocopying, or recording by or in an information storage and retrieval system) without its advance written permission. For information on permission to copy material from the IFC exceeding fair use, please contact: International Code Council, Attn: ICC General Counsel, Birmingham Regional Office, 900 Montclair Road, Birmingham, AL 35213-1206.