

To Be Rescinded1301:7-7-17 Matches.

(A) Section FM-1701.0 General

(1) FM-1701.1 Scope: The equipment, processes and operations for the storage, handling or manufacturing of matches shall comply with this rule.

(2) F-1701.2 ~~Permit~~ APPROVAL required: ~~A permit~~ APPROVAL shall be obtained from the code official for the manufacture or storage of matches exceeding 25 cases in aggregate.

(B) Section F-1702.0 Fire safety requirements


(1) F-1702.1 Vertical openings: Matches exceeding 50 pounds (~~22.723~~ kg), including the containers, shall not be stored within 10 feet (3048 mm) of any elevator shaft, elevator shaft opening, open stairway or the vertical opening.

(2) F-1702.2 Sources of ignition: Matches shall not be stored within 10 feet (3048 mm) of any boiler, furnace, stove, open flame or similar source of ignition.

(3) F-1702.3 Storage: Where containers of matches are stored in piles exceeding 100 cubic feet (~~2.8~~ 3 m³), the piles shall be arranged with a maximum height of 10 feet (3048 mm) and a maximum volume of 1,500 cubic feet (42 m³), with aisles at least 8 feet (2438 mm) wide.

(4) F-1702.4 Housekeeping: Where shipping containers containing matches are opened, the contents of the opened containers shall be removed and stored in metal or metal-lined bins equipped with self-closing covers.

Effective: March 30, 1998


Certification

March 12, 1998
Date

Promulgated under:	R.C. Section 119.03
Rule amplifies:	R.C. Section 3737.22
Authorized by:	R.C. Section 3737.82
R.C. 119.032 Review Date:	1/01/03
Prior effective date:	7/01/79;6/01/85;6/15/92;7/1/93;9/1/95

Effective:

R.C. 119.032 review dates: 11/23/2004

Certification

Date

Promulgated Under: 119.03
Statutory Authority: 3737.82, 3737.86
Rule Amplifies: N/A
Prior Effective Dates: 7/1/79, 6/1/85, 6/15/92, 7/1/93, 9/1/95, 3/30/98