

TO BE RESCINDED

1301:7-7-24 **Tents and other membrane structures.**

(A) Section 2401 General

- (1) 2401.1 Scope. Tents, canopies and membrane structures shall comply with this rule. The provisions of paragraph (C)(2403) of this rule are applicable only to temporary membrane structures. The provisions of paragraph (D)(2404) of this rule are applicable to temporary and permanent membrane structures.

(B) Section 2402 Definitions

- (1) 2402.1 Definitions. The following words and terms shall, for the purposes of this rule and as used elsewhere in this code, have the meanings shown herein.

"Air-supported structure." A structure wherein the shape of the structure is attained by air pressure, and occupants of the structure are within the elevated pressure area.

"Canopy." A structure, enclosure or shelter constructed of fabric or pliable materials supported by any manner, except by air or the contents it protects, and is open without sidewalls or drops on 75 per cent or more of the perimeter.

"Membrane structure." An air-inflated, air-supported, cable or frame-covered structure as defined by the building code as listed in rule 1301:7-7-45 of the Administrative Code and not otherwise defined as a tent or canopy. See Chapter 31 of the building code as listed in rule 1301:7-7-45 of the Administrative Code.

"Tent." A structure, enclosure or shelter constructed of fabric or pliable material supported by any manner except by air or the contents that it protects.

(C) Section 2403 Temporary tents, canopies and membrane structures

- (1) 2403.1 General. All temporary tents, canopies and membrane structures shall comply with the paragraph.
- (2) 2403.2 Approval required. Tents and membrane structures having an area in excess of 200 square feet (19 m²) and canopies in excess of 400 square feet (37 m²) shall not be erected, operated or maintained for any purpose without first obtaining a permit and approval from the fire code official.

Note: for copyright claim information, please see the notice on the last page of this rule.

Exceptions:

1. Tents used exclusively for recreational camping purposes.
2. Fabric canopies open on all sides which comply with all of the following:
 - 2.1 Individual canopies having a maximum size of 700 square feet (65 m²).
 - 2.2 The aggregate area of multiple canopies placed side by side without a fire break clearance of 12 feet (3658 mm), not exceeding 700 square feet (65 m²) total.
 - 2.3 A minimum clearance of 12 feet (3658 mm) to all structures and other tents.
- (3) 2403.3 Place of assembly. For the purposes of this rule, a place of assembly shall include a circus, carnival, tent show, theater, skating rink, dance hall or other place of assembly in or under which persons gather for any purpose.
- (4) 2403.4 Permits. Permits shall be required as set forth in rule 1301:7-7-01 of the Administrative Code.
- (5) 2403.5 Use period. Temporary tents, air-supported, air-inflated or tensioned membrane structures and canopies shall not be erected for a period of not more than 180 days within a 12-month period on a single premise.
- (6) 2403.6 Construction documents. A detailed site and floor plan for tents, canopies or membrane structures with an occupant load of 50 or more shall be provided with each application for approval. The tent, canopy or membrane structure floor plan shall indicate details of the means of egress facilities, seating capacity, arrangement of the seating and location and type of heating and electrical equipment.
- (7) 2403.7 Inspections. The entire tent, air-supported, air-inflated or tensioned membrane structure system shall be inspected at regular intervals, but not less than two times per permit use period, by the permittee, owner or agent to determine that the installation is maintained in accordance with this rule.

Exception: Permit use periods of less than 30 days.

- (a) 2403.7.1 Inspection report. When required by the fire code official, an inspection report shall be provided and shall consist of maintenance, anchors and fabric inspections.

Note: for copyright claim information, please see the notice on the last page of this rule.

(8) 2403.8 Access, location and parking. Access, location and parking for temporary tents, canopies and membrane structures shall be in accordance with this paragraph.

(a) 2403.8.1 Access. Fire apparatus access roads shall be provided in accordance with paragraph (C)(503) of rule 1301:7-7-05 of the Administrative Code.

(b) 2403.8.2 Location. Tents, canopies or membrane structures shall not be located within 20 feet (6096 mm) of lot lines, buildings, other tents, canopies or membrane structures, parked vehicles or internal combustion engines. For the purpose of determining required distances, support ropes and guy wires shall be considered as part of the temporary membrane structure, tent or canopy.

Exceptions:

1. Separation distance between membrane structures, tents and canopies not used for cooking, is not required when the aggregate floor area does not exceed 15,000 square feet (1394 m²).

2. Membrane structures, tents or canopies need not be separated from buildings when all of the following conditions are met:

2.1 The aggregate floor area of the membrane structure, tent or canopy shall not exceed 10,000 square feet (929 m²).

2.2 The aggregate floor area of the building and membrane structure, tent or canopy shall not exceed the allowable floor area including increases as indicated in the building code as listed in rule 1301:7-7-45 of the Administrative Code.

2.3 Required means of egress provisions are provided for both the building and the membrane structure, tent or canopy, including travel distances.

2.4 Fire apparatus access roads are provided in accordance with paragraph (C)(503) of rule 1301:7-7-05 of the Administrative Code.

(c) 2403.8.3 Location of structures in excess of 15,000 square feet in area. Membrane structures having an area of 15,000 square feet (1394 m²) or more shall be located not less than 50 feet (15 240 mm) from any other tent or structure as measured from the sidewall of the tent or membrane structure unless jointed together by a corridor.

Note: for copyright claim information, please see the notice on the last page of this rule.

- (d) 2403.8.4 Connecting corridors. Tents or membrane structures are allowed to be joined together by means of corridors. Exit doors shall be provided at each end of such corridor. On each side of such corridor and approximately opposite each other, there shall be provided openings not less than 12 feet (3658 mm) wide.
- (e) 2403.8.5 Fire break. An unobstructed fire break passageway or fire road not less than 12 feet (3658 mm) wide and free from guy ropes or other obstructions shall be maintained on all sides of all tents, canopies and membrane structures unless otherwise approved by the fire code official.
- (9) 2403.9 Anchorage required. Tents, canopies or membrane structures and their appurtenances shall be adequately roped, braced and anchored to withstand the elements of weather and prevent against collapsing. Documentation of structure stability shall be furnished to the fire code official on request.
- (10) 2403.10 Temporary air-supported and air-inflated membrane structures. Temporary air-supported and air-inflated membrane structures shall be in accordance with paragraphs (C)(10)(a)(2403.10.1) to (C)(10)(d)(2403.10.4) of this rule.
- (a) 2403.10.1 Door operation. During high winds exceeding 50 miles per hour (80 kph) or in snow conditions, the use of doors in air-supported structures shall be controlled to avoid excessive air loss. Doors shall not be left open.
- (b) 2403.10.2 Fabric envelope design and construction. Air-supported and air-inflated structures shall have the design and construction of the fabric envelope and the method of anchoring in accordance with "Architectural Fabric Structures Institute" ASI 77 as listed in rule 1301:7-7-45 of the Administrative Code.
- (c) 2403.10.3 Blowers. An air-supported structure used as a place of assembly shall be furnished with not less than two blowers, each of which has adequate capacity to maintain full inflation pressure with normal leakage. The design of the blower shall be so as to provide integral limiting pressure at the design pressure specified by the manufacturer.
- (d) 2403.10.4 Auxiliary power. Places of public assembly for more than 200 persons shall be furnished with either a fully automatic auxiliary engine-generator set capable of powering one blower continuously for 4

Note: for copyright claim information, please see the notice on the last page of this rule.

hours, or a supplementary blower powered by an internal combustion engine which shall be automatic in operation.

- (11) 2403.11 Seating arrangements. Seating in tents, canopies or membrane structures shall be in accordance with rule 1301:7-7-10 of the Administrative Code.
- (12) 2403.12 Means of egress. Means of egress for temporary tents, canopies and membrane structures shall be in accordance with paragraphs (C)(12)(a)(2403.12.1) to (C)(12)(h)(2403.12.8) of this rule.
- (a) 2403.12.1 Distribution. Exits shall be spaced at approximately equal intervals around the perimeter of the tent, canopy or membrane structure, and shall be located such that all points are 100 feet (30 480 mm) or less from an exit.
- (b) 2403.12.2 Number. Tents, canopies or membrane structures or a usable portion thereof shall have at least one exit and not less than the number of exits required by Table 2403.12.2 of this rule. The total width of means of egress required by Table 2403.12.2 of this rule shall not be less than the total occupant load served by a means of egress multiplied by 0.2 inches (5 mm) per person.

Table 2403.12.2

Minimum number of means of egress and means of egress widths from temporary membrane structures, tents and canopies

<u>Occupant load</u>	<u>Minimum number of means of egress</u>	<u>Minimum width of each means of egress (inches)</u>	
		<u>Tent or canopy</u>	<u>Membrane structure</u>
<u>10 to 199</u>	<u>2</u>	<u>72</u>	<u>36</u>
<u>200 to 499</u>	<u>3</u>	<u>72</u>	<u>72</u>
<u>500 to 999</u>	<u>4</u>	<u>96</u>	<u>72</u>
<u>1,000 to 1,999</u>	<u>5</u>	<u>120</u>	<u>96</u>
<u>2,000 to 2,999</u>	<u>6</u>	<u>120</u>	<u>96</u>
<u>Over 3,000^a</u>	<u>7</u>	<u>120</u>	<u>96</u>

For SI: 1 inch = 25.4 mm.

a. When the occupant load exceeds 3,000, the total width of means of egress in inches shall not be less than the total occupant load multiplied

Note: for copyright claim information, please see the notice on the last page of this rule.

by 0.2 inches per person.

(c) 2403.12.3 Exit openings from tents. Exit openings from tents shall remain open unless covered by a flame-resistant curtain. The curtain shall comply with the following requirements:

(i) Curtains shall be free sliding on a metal support. The support shall be a minimum of 80 inches (2032 mm) above the floor level at the exit. The curtains shall be so arranged that, when open, no part of the curtain obstructs the exit.

(ii) Curtains shall be of a color, or colors, that contrasts with the color of the tent.

(d) 2403.12.4 Doors. Exit doors shall swing in the direction of exit travel. To avoid hazardous air and pressure loss in air-supported membrane structures, such doors shall be automatic closing against operating pressures. Opening force at the door edge shall not exceed 15 pounds (66 N).

(e) 2403.12.5 Aisle. The width of aisles without fixed seating shall be in accordance with the following:

1. In areas serving employees only, the minimum aisle width shall be 24 inches (610 mm) but not less than the width required by the number of employees served.

2. In public areas, smooth-surfaced, unobstructed aisles having a minimum width of not less than 44 inches (1118 mm) shall be provided from seating areas, and aisles shall be progressively increased in width to provide, at all points, not less than 1 foot (305 mm) of aisle width for each 50 persons served by such aisle at that point.

(i) 2403.12.5.1 Arrangement and maintenance. The arrangement of aisles shall be subject to approval by the fire code official and shall be maintained clear at all times during occupancy.

(f) 2403.12.6 Exit signs. Exits shall be clearly marked. Exit signs shall be installed at required exit doorways and where otherwise necessary to indicate clearly the direction of egress when the exit serves an occupant load of 50 or more.

(i) 2403.12.6.1 Exit sign illumination. Exit signs shall be of an approved self-luminous type or shall be internally or externally illuminated by luminaires supplied in the following manner:

(a) Two separate circuits, one of which shall be separate from all other circuits, for occupant loads of 300 or less; or

(b) Two separate sources of power, one of which shall be an approved emergency system, shall be provided when the occupant load exceeds 300. Emergency systems shall be supplied from storage batteries or from the on-site generator set, and the system shall be installed in accordance with the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code.

(g) 2403.12.7 Means of egress illumination. Means of egress shall be illuminated with light having an intensity of not less than 1 foot-candle (11 lux) at floor level while the structure is occupied. Fixtures required for means of egress illumination shall be supplied from a separate circuit or source of power.

(h) 2403.12.8 Maintenance of means of egress. The required width of exits, aisles and passageways shall be maintained at all times to a public way. Guy wires, guy ropes and other support members shall not cross a means of egress at a height of less than 8 feet (2438 mm). The surface of means of egress shall be maintained in an approved manner.

(D) Section 2404 Temporary and permanent tents, canopies and membrane structures

(1) 2404.1 General. All tents, canopies and membrane structures, both temporary and permanent, shall be in accordance with this paragraph. Permanent tents, canopies and membrane structures shall also comply with the building code as listed in rule 1301:7-7-45 of the Administrative Code.

(2) 2404.2 Flame propagation performance. Before a permit is granted, the owner or agent shall file with the fire code official a certificate executed by an approved testing laboratory, certifying that the tents, canopies and membrane structures and their appurtenances, sidewalls, drops and tarpaulins, floor coverings, bunting, combustible decorative materials and effects, including sawdust when used on floors or passageways, shall be composed of material meeting the flame propagation performance criteria of NFPA 701 as listed in rule 1301:7-7-45 of the Administrative Code or shall be treated with a flame

Note: for copyright claim information, please see the notice on the last page of this rule.

retardant in an approved manner and meet the flame propagation performance criteria of NFPA 701 as listed in rule 1301:7-7-45 of the Administrative Code, and that such flame propagation performance criteria are effective for the period specified by the permit.

- (3) 2404.3 Label. Membrane structures, tents or canopies shall have a permanently affixed label bearing the identification of size and fabric or material type.
- (4) 2404.4 Certification. An affidavit or affirmation shall be submitted to the fire code official and a copy retained on the premises on which the tent or air-supported structure is located. The affidavit shall attest to the following information relative to the flame propagation performance criteria of the fabric:
 - (a) Names and address of the owners of the tent, canopy or air-supported structure.
 - (b) Date the fabric was last treated with flame- retardant solution.
 - (c) Trade name or kind of chemical used in treatment.
 - (d) Name of person or firm treating the material.
 - (e) Name of testing agency and test standard by which the fabric was tested.
- (5) 2404.5 Combustible materials. Hay, straw, shavings or similar combustible materials shall not be located within any tent, canopy or membrane structure containing an assembly occupancy, except the materials necessary for the daily feeding and care of animals. Sawdust and shavings utilized for public performance or exhibit shall not be prohibited provided the sawdust and shaving are kept damp. Combustible materials shall not be permitted under stands or seats at any time. The areas within and adjacent to the tent or air-supported structure shall be maintained clear of all combustible materials or vegetation that could create a fire hazard within 20 feet (6096 mm) from the structure. Combustible trash shall be removed at least once a day from the structure during the period the structure is occupied by the public.
- (6) 2404.6 Smoking. Smoking shall not be permitted in tents, canopies or membrane structures. Approved "No Smoking" signs shall be conspicuously posted in accordance with paragraph (J)(310) of rule 1301:7-7-03 of the Administrative Code.

Note: for copyright claim information, please see the notice on the last page of this rule.

- (7) 2404.7 Open or exposed flame. Open flame or other devices emitting flame, fire or heat or any flammable or combustible liquids, gas, charcoal or other cooking device or any other unapproved devices shall not be permitted inside or located within 20 feet (6096 mm) of the tent, canopy or membrane structures while open to the public unless approved by the fire code official.
- (8) 2404.8 Fireworks. Fireworks shall not be used within 100 feet (30 480 mm) of tents, canopies or membrane structures.
- (9) 2404.9 Spot lighting. Spot or effect lighting shall only be by electricity, and all combustible construction located within 6 feet (1829 mm) of such equipment shall be protected with approved noncombustible insulation not less than 9.25 inches (235 mm) thick.
- (10) 2404.10 Safety film. Motion pictures shall not be displayed in tents, canopies or membrane structures unless the motion picture film is safety film.
- (11) 2404.11 Clearance. There shall be a minimum clearance of at least 3 feet (914 mm) between the fabric envelope and all contents located inside the tent or membrane structure.
- (12) 2404.12 Portable fire extinguishers. Portable fire extinguishers shall be provided as required by paragraph (F)(906) of rule 1301:7-7-09 of the Administrative Code.
- (13) 2404.13 Fire protection equipment. Fire hose lines, water supplies and other auxiliary fire equipment shall be maintained at the site in such numbers and sizes as required by the fire code official.
- (14) 2404.14 Occupant load factors. The occupant load allowed in an assembly structure, or portion thereof, shall be determined in accordance with rule 1301:7-7-10 of the Administrative Code.
- (15) 2404.15 Heating and cooking equipment. Heating and cooking equipment shall be in accordance with paragraphs (D)(15)(a)(2404.15.1) to (D)(15)(g)(2404.15.7) of this rule.
- (a) 2404.15.1 Installation. Heating or cooking equipment, tanks, piping, hoses, fittings, valves, tubing and other related components shall be installed as specified in the mechanical code and the International Fuel Gas Code as listed in rule 1301:7-7-45 of the Administrative Code, and

Note: for copyright claim information, please see the notice on the last page of this rule.

shall be approved by the fire code official.

- (b) 2404.15.2 Venting. Gas, liquid and solid fuel-burning equipment designed to be vented shall be vented to the outside air as specified in the International Fuel Gas Code and the mechanical code as listed in rule 1301:7-7-45 of the Administrative Code. Such vents shall be equipped with approved spark arresters when required. Where vents or flues are used, all portions of the tent, canopy or membrane structure shall be not less than 12 inches (305 mm) from the flue or vent.
 - (c) 2404.15.3 Location. Cooking and heating equipment shall not be located within 10 feet (3048 mm) of exits or combustible materials.
 - (d) 2404.15.4 Operations. Operations such as warming of foods, cooking demonstrations and similar operations that use solid flammables, butane or other similar devices which do not pose an ignition hazard, shall be approved.
 - (e) 2404.15.5 Cooking tents. Tents where cooking is performed shall be separated from other tents, canopies or membrane structures by a minimum of 20 feet (6096 mm).
 - (f) 2404.15.6 Outdoor cooking. Outdoor cooking that produces sparks or grease-laden vapors shall not be performed within 20 feet (6096 mm) from a tent, canopy or membrane structure.
 - (g) 2404.15.7 Electrical heating and cooking equipment. Electrical cooking and heating equipment shall comply with the building code and NFPA 70 as listed in rule 1301:7-7-45 of the Administrative Code.
- (16) 2404.16 LP-gas. The storage, handling and use of LP-gas and LP-gas equipment shall be in accordance with paragraphs (D)(16)(a)(2406.16.1) to (D)(16)(c)(2404.16.3) of this rule.
- (a) 2404.16.1 General. LP-gas equipment such as tanks, piping, hoses, fittings, valves, tubing and other related components shall be approved and in accordance with rule 1301:7-7-38 of the Administrative Code and with the International Fuel Gas Code as listed in rule 1301:7-7-45 of the Administrative Code.
 - (b) 2404.16.2 Location of containers. LP-gas containers shall be located outside. Safety release valves shall be pointed away from the tent,

Note: for copyright claim information, please see the notice on the last page of this rule.

canopy or membrane structure.

- (i) 2404.16.2.1 Containers 500 gallons or less. Portable LP-gas containers with a capacity of 500 gallons (1893 L) or less shall have a minimum separation between the container and structure not less than 10 feet (3048 mm).
 - (ii) 2404.16.2.2 Containers more than 500 gallons. Portable LP-gas containers with a capacity of more than 500 gallons (1893 L) shall have a minimum separation between the container and structures not less than 25 feet (7620 mm).
 - (iii) 2404.16.2.3 Protection and security. Portable LP-gas containers, piping, valves and fittings which are located outside and are being used to fuel equipment inside a tent, canopy or membrane structure shall be adequately protected to prevent tampering, damage by vehicles or other hazards and shall be located in an approved location. Portable LP-gas containers shall be securely fastened in place to prevent unauthorized movement.
- (17) 2404.17 Flammable and combustible liquids. The storage of flammable and combustible liquids and the use of flammable-liquid-fueled equipment shall be in accordance with paragraphs (D)(17)(a)(2404.17.1) to (D)(17)(c)(2404.17.3) of this rule.
- (a) 2404.17.1 Use. Flammable-liquid-fueled equipment shall not be used in tents, canopies or membrane structures.
 - (b) 2404.17.2 Flammable and combustible liquid storage. Flammable and combustible liquids shall be stored outside in an approved manner not less than 50 feet (15 240 mm) from tents, canopies or membrane structures. Storage shall be in accordance with rule 1301:7-7-34 of the Administrative Code.
 - (c) 2404.17.3 Refueling. Refueling shall be performed in an approved location not less than 20 feet (6096 mm) from tents, canopies or membrane structures.
- (18) 2404.18 Display of motor vehicles. Liquid- or gas-fueled vehicles and equipment used for display within tents, canopies or membrane structures shall be in accordance with paragraphs (D)(18)(a)(2404.18.1) to (D)(18)(e)(iii)(2404.18.5.3) of this rule.

Note: for copyright claim information, please see the notice on the last page of this rule.

- (a) 2404.18.1 Batteries. Batteries shall be disconnected in an appropriate manner.
- (b) 2404.18.2 Fuel systems. Vehicles or equipment shall not be fueled or defueled within the tent, canopy or membrane structure.
 - (i) 2404.18.2.1 Quantity limit. Fuel in the fuel tank shall not exceed one-quarter of the tank capacity or 5 gallons (19L), whichever is less.
 - (ii) 2404.18.2.2 Inspection. Fuel systems shall be inspected for leaks.
 - (iii) 2404.18.2.3 Closure. Fuel tank openings shall be locked and sealed to prevent the escape of vapors.
- (c) 2404.18.3 Location. The location of vehicles or equipment shall not obstruct means of egress.
- (d) 2404.18.4 Places of assembly. When a compressed natural gas (CNG) or liquefied petroleum gas (LP-gas) powered vehicle is parked inside a place of assembly, all the following conditions shall be met:
 - (i) The quarter-turn shutoff valve or other shutoff valve on the outlet of the CNG or LP-gas container shall be closed and the engine shall be operated until it stops. Valves shall remain closed while the vehicle is indoors.
 - (ii) The hot lead of the battery shall be disconnected.
 - (iii) Dual-fuel vehicles equipped to operate on gasoline or CNG or LP-gas shall comply with this paragraph and paragraphs (D)(18)(a)(2404.18.1) to (D)(18)(e)(iii)(2404.18.5.3) of this rule for gasoline-powered vehicles.
- (e) 2404.18.5 Competitions and demonstrations. Liquid- and gas-fueled vehicles and equipment used for competition or demonstration within a tent, canopy or membrane structure shall comply with paragraphs (D)(18)(e)(i)(2404.18.5.1) to (D)(18)(e)(iii)(2404.18.5.3) of this rule.
 - (i) 2404.18.5.1 Fuel storage. Fuel for vehicles or equipment shall be

Note: for copyright claim information, please see the notice on the last page of this rule.

stored in approved containers in an approved location outside of the structure in accordance with paragraph (D)(17)(b)(2404.17.2) of this rule.

(ii) 2404.18.5.2 Fueling. Refueling shall be performed outside of the structure in accordance with paragraph (D)(17)(c)(2404.17.3) of this rule.

(iii) 2404.18.5.3 Spills. Fuel spills shall be cleaned up immediately.

(19) 2404.19 Separation of generators. Generators and other internal combustion power sources shall be separated from tents, canopies or membrane structures by a minimum of 20 feet (6096 mm) and shall be isolated from contact with the public by fencing, enclosure or other approved means.

(20) 2404.20 Standby personnel. When, in the opinion of the fire code official, it is essential for public safety in a tent, canopy or membrane structure used as a place of assembly or any other use where people congregate, because of the number of persons, or the nature of the performance, exhibition, display, contest or activity, the owner, agent or lessee shall employ one or more qualified persons, as required and approved, to remain on duty during the times such places are open to the public, or when such activity is being conducted.

Before each performance or the start of such activity, standby personnel shall keep diligent watch for fires during the time such place is open to the public or such activity is being conducted and take prompt measures for extinguishment of fires that occur and assist in the evacuation of the public from the structure.

There shall be trained crowd managers or crowd manager supervisors at a ratio of one crowd manager/supervisor for every 250 occupants, as approved.

(21) 2404.21 Vegetation removal. Combustible vegetation shall be removed from the area occupied by a tent, canopy or membrane structure, and from areas within 30 feet (9144 mm) of such structures.

(22) 2404.22 Waste material. The floor surface inside tents, canopies or membrane structures and the grounds outside and within a 30-foot (9144 mm) perimeter shall be kept clear of combustible waste. Such waste shall be stored in approved containers until removed from the premises.

Note: for copyright claim information, please see the notice on the last page of this rule.

Effective:

R.C. 119.032 review dates: 05/18/2011

Certification

Date

Promulgated Under: 119.03
Statutory Authority: 3737.22, 3737.82
Rule Amplifies: N/A
Prior Effective Dates: 7/1/79, 6/1/85, 6/15/92, 7/1/93, 9/1/95, 3/30/98,
9/1/05, 7/1/07

Copyright Claim Information

The Ohio Fire Code ("OFC") designates and incorporates substantial portions of the ICC INTERNATIONAL FIRE CODE/2003, a copyrighted work owned by the International Code Council. The International Code Council, Inc., Falls Church, Virginia ("ICC") asserts a copyright in those portions of the OFC based upon the International Fire Code/2003.

The ICC asserts that no part of the International Fire Code/2003, as an independent document, may be reproduced, distributed, or transmitted in any form or by any means, including, without limitation, electronic, optical, or mechanical means (by way of example, and not limitation, photocopying, or recording by or in an information storage and retrieval system) without its advance written permission. For information on permission to copy material from the IFC exceeding fair use, please contact: International Code Council, Attn: ICC General Counsel, Birmingham Regional Office, 900 Montclair Road, Birmingham, AL 35213-1206.