

TO BE RESCINDED

4901:1-15-13 **Emergency operations.**

- (A) Within one year after the effective date of this rule, each waterworks company and/or sewage disposal system company shall make every reasonable effort to have on site, within twenty-four hours of a failure of any system component that would prohibit the company from providing service to any of its customers, necessary back-up equipment to keep its system in operation. The company shall maintain a current inventory record and a list of sources of back-up equipment.
- (B) Each waterworks company and/or sewage disposal system company shall have posted both in its plant(s) and office(s) a list of procedures to be followed in the event of a failure of its system as described in paragraph (A) of this rule. The names, addresses, and telephone numbers of key operating personnel shall be posted in a convenient area. This list shall be updated at least annually and be available to the commission.
- (C) Each waterworks company and/or sewage disposal system company shall have a twenty-four hour emergency telephone number published in the local telephone directory applicable to the local service territory under the company name by which company operating personnel can be readily reached.
- (D) When a waterworks company and/or sewage disposal system company has a failure of its system, it shall promptly notify the emergency coordinator of the commission.

Effective:

R.C. 119.032 review dates: 12/30/2002

Certification

Date

Promulgated Under: 111.15
Statutory Authority: 4905.04
Rule Amplifies: 4905.06
Prior Effective Dates: 6/1/77, 10/30/87, 12/12/91