

TO BE RESCINDED

4901:5-37-02 **Emergency reporting to the commission; emergency actions.**

(A) Each electric utility shall promptly report to the commission:

- (1) Any loss in service for fifteen minutes or more of electric power supply to a firm load of one hundred megawatts or more;
- (2) Any action to reduce firm customer loads in order to maintain reliability of the power supply system;
- (3) Any appeal for the public to conserve electricity;
- (4) Any action to reduce firm customer loads by manual switching, automatic load shedding, or other means used to maintain reliability of the power supply system;
- (5) Any outage or incident which damages or renders inoperable system equipment located in Ohio;
- (6) When a transmission company determines that a net operating reserve deficiency will exist for the next calendar day and power supply and/or operating reserve cannot be obtained or purchased; and
- (7) Any action taken pursuant to the rules of this chapter.

Each report shall be made by fax, voice mail, personal contact or other commission determined means with a designated commission representative.

(B) When an electric utility is unable to relieve an existing or anticipated energy shortage by obtaining or purchasing power through an interconnected system pursuant to rules 4901:1-22-03, 4901:1-22-04, and 4901:1-22-05 of the Administrative Code, each company shall implement and follow:

- (1) ECAR's load shedding procedures;
- (2) The provision of the company's emergency plan, as approved by the commission.

Effective: 02/27/2010

R.C. 119.032 review dates: 10/20/2009

CERTIFIED ELECTRONICALLY

Certification

02/16/2010

Date

Promulgated Under: 111.15
Statutory Authority: 4935.03
Rule Amplifies: 4935.03
Prior Effective Dates: 9/18/2000