

TO BE RESCINDED

4901:5-37-03

Sudden or unanticipated emergency resulting in overloading transmission facilities.

When sudden or unanticipated generation or transmission outages cause an overloading of the electric utility's facilities or interconnection circuits which operate at a nominal sixty hertz, each company shall perform any or all of the following actions, as required:

- (A) Interrupt service to customers served under interruptible tariffs or contracts;
- (B) Interrupt service to firm service customers;
- (C) Reduce voltage not more than five per cent if the transmission system is isolated;
and/or
- (D) Disconnect the overloaded facility or circuit.

Effective:

R.C. 119.032 review dates: 10/20/2009

Certification

Date

Promulgated Under: 111.15
Statutory Authority: 4935.03
Rule Amplifies: 4935.03
Prior Effective Dates: 9/18/2000