

3745-18-11

Athens county emission limits.

- (A) No owner or operator of any coal-fired steam generating unit in Athens county, unless otherwise specified in this rule, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.
- (B) [Reserved.]
- (C) The "Ohio University-Lausche Heating Plant" (OEPA premise number 0605010016) or any subsequent owner or operator of the "Ohio University-Lausche Heating Plant, Factory Street, Athens, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler ~~numbers number 136641, 136642, and 136643~~ (OEPA source ~~numbers number B043, B042 and B041~~) to exceed a maximum of 4.7 pounds of sulfur dioxide per MM Btu actual heat input from ~~each~~the boiler.

Effective: 2/3/2022

Five Year Review (FYR) Dates: 11/9/2021 and 11/09/2026

CERTIFIED ELECTRONICALLY

Certification

01/24/2022

Date

Promulgated Under: 119.03
Statutory Authority: 3704.03(E)
Rule Amplifies: 3704.03(A), 3704.03(E)
Prior Effective Dates: 12/28/1979, 06/15/1989, 01/23/2006, 02/17/2011,
02/16/2017