

3745-18-11

Athens county emission limits.

(A) No owner or operator of any coal-fired steam generating unit, unless otherwise specified below, shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 4.5 pounds of sulfur dioxide per MM Btu actual heat input.

(B) [Reserved]

(C) The "Ohio University-Lausche Heating Plant" (OEPA premise number 0605010016) or any subsequent owner or operator of the "Ohio University-Lausche Heating Plant, Factory Street, Athens, Ohio" shall not cause or permit the emission of sulfur dioxide from boiler numbers 136641, 136642, and 136643 (OEPA source numbers B041 through B043) to exceed a maximum of 4.7 pounds of sulfur dioxide per MM Btu actual heat input from each boiler.

Replaces: 3745-18-11
Effective: 02/17/2011
R.C. 119.032 review dates: 11/30/2015

CERTIFIED ELECTRONICALLY

Certification

02/07/2011

Date

Promulgated Under: 119.03
Statutory Authority: 3704.03(E)
Rule Amplifies: 3704.03(A), 3704.03(E)
Prior Effective Dates: 12/28/79, 6/15/89, 1/23/06