

3745-18-12

Auglaize county emission limits.

No owner or operator of any coal-fired steam generating unit in Auglaize county shall cause or permit the emission of sulfur dioxide from any source to exceed a maximum of 2.6 pounds of sulfur dioxide per MM Btu actual heat input.

Replaces: 3745-18-12

Effective:

Five Year Review (FYR) Dates:

Certification

Date

Promulgated Under: 119.03
Statutory Authority: 3704.03(E)
Rule Amplifies: 3704.03(A), 3704.03(E)
Prior Effective Dates: 12/28/79, 1/23/06, 2/17/11