

3745-267-198**General operating requirements - tank systems - standardized permitting.**

- (A) Owners or operators shall not place hazardous wastes or treatment reagents in a tank system if the hazardous wastes or treatment reagents could cause the tank, the tank's ancillary equipment, or the containment system to rupture, leak, corrode, or otherwise fail.
- (B) Owners or operators shall use appropriate controls and practices to prevent spills and overflows from tank or containment systems. These include, at a minimum:
- (1) Spill prevention controls (for example, check valves, dry disconnect couplings).
  - (2) Overfill prevention controls (for example, level sensing devices, high level alarms, automatic feed cutoff, or bypass to a standby tank).
  - (3) Sufficient freeboard in uncovered tanks to prevent overtopping by wave or wind action or by precipitation.
- (C) Owners or operators shall comply with the requirements of rule 3745-267-200 of the Administrative Code if a leak or spill occurs in the tank system.

Effective:

Five Year Review (FYR) Dates: Exempt

---

Certification

---

Date

Promulgated Under:	119.03
Statutory Authority:	3734.12
Rule Amplifies:	3734.12