

**4101:2-11-01 Refrigeration.**

Chapter 11 of the International Mechanical Code, ~~2021~~ 2024 edition, ~~is as~~ incorporated by reference and modified in Section 101.1.1 of this code, is further modified as follows:

**(A) Replace exception #2 under section 1109.2.5 to read as follows:**

2. Piping in a direct refrigeration system where the refrigerant quantity does not exceed the limits of [Table 1103.1](#) for the smallest occupied space through which the piping passes.

Replaces: 4101:2-11-01

Effective:

Five Year Review (FYR) Dates:

---

Certification

---

Date

Promulgated Under: 119.03

Statutory Authority: 3781.10(A)(1), 4104.43 (A)(1)

Rule Amplifies: 3781.10, 3781.11, 3791.04

Prior Effective Dates: 03/01/1998, 01/01/2002, 01/01/2004, 03/01/2005,  
07/01/2007, 11/01/2007, 11/01/2011, 11/01/2017,  
03/01/2024